



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

June 2, 2008

RE: LAKE COUNTY
LAKE COUNTY WATER PLANT - EAST
NPDES PERMIT NO. 3IV00260
NOTICE OF VIOLATION

Mr. Richard V. Douglas, II
Lake County Water Plant - East
1845 Lake Road
Painesville, OH 44077

Dear Mr. Douglas:

This office has recently reviewed your self-monitoring reports for the above referenced facility covering the period of December 2007 through March 2008. Our review indicates violation(s) of the terms and conditions of your NPDES permit. The specific instance(s) of noncompliance are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00530	Total Suspended Solids	30D Conc	30	45.	3/1/2008
001	00530	Total Suspended Solids	30D Conc	30	43.	12/1/2007

Please be advised that such instances of noncompliance may be cause for enforcement actions pursuant to the Ohio Revised Code, Chapter 6111.

We have reviewed your report addressing the reason for the above referenced violations and the actions being taken to prevent further occurrences. No additional information is requested at this time.

If there are any questions or comments regarding this notification, please contact this office at (330) 963-1183.

Sincerely,

Marie Underwood, P.E.
Environmental Engineer
Division of Surface Water

MU/mt