



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Rd.
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

RE: Crawford County
Foxfire Campgrounds
NPDES Permit

June 30, 2009

Mr. Jake Seeman, Owner
Foxfire Campgrounds
3699 Crawford-Wyandot Road
Nevada, Ohio 44849

Dear Mr. Seeman:

On June 2, 2009, an inspection was made of the wastewater treatment facilities serving the Foxfire Campgrounds located at 3699 Crawford-Wyandot Road, Todd Township, Crawford County. No major operational concerns were noted at the time of inspection.

The aeration tanks had a healthy brown color and were receiving an adequate amount of air. The clarifier appeared to be working well. The sand filters had some solids on them and some vegetation growth. Chlorine tablets were observed in the tablet feeder, but no dechlorination facilities were observed.

A review of your discharge monitoring reports has shown violations of your limits for the months July 2006 through May 2009. In addition, there are instances over that time period where you have not reported all of your required data. The specific instances are attached to this letter. If you have any questions about reporting, please contact this office.

If you have any questions, please call me at 419-373-3019.

Sincerely,

Michelle Sharp
Environmental Specialist II
Division of Surface Water

/lb

Enclosure

Pc: ~~DSW-NWDO w/enclosures~~
Crawford County Health Department w/enclosures

OHIO ENVIRONMENTAL PROTECTION AGENCY

OPERATION AND MAINTENANCE INSPECTION
WWTP'S LESS THAN 25,000 GPD

NPDES Permit No. 2PRO0201

Facility Name Foxfire Campground Expiration Date Nov 30, 2009

Facility Address 3699 Crawford-Wyandot Rd Date 6-2-09 Time 10:00 am

City Nevada County Crawford Township _____

Name and Address of Owner Mr. Jake Seeman - Same as above

Person Contacted Mr Jake Seeman Owner Phone 740-482-2190

Flow: Design 9,000 GPD Present _____ GPD (metered - estimated)

Trib. Pop. _____ (actual - estimated) Weather at time of inspection: Temp 60° Cloudy

OEPA Personnel Michelle Sharp District NWDO

1. Plant Effluent - Mark Severity No.

No.	Severity Description	No.	Turbidity	No.	Odor	No.	Color
0	None	<input checked="" type="checkbox"/>	Clear	<input checked="" type="checkbox"/>	None	<input checked="" type="checkbox"/>	Colorless
1	Mild						
2	Moderate		Light Solids		Musty		Grey
3	Serious						
4	Extreme		Heavy Solids		Septic		Black

2. Effect of effluent on Receiving Stream Name: Not Observed

No.	Severity Description	No.	Turbidity	No.	Odor	No.	Color
0	None		Clear		None		Colorless
1	Mild						
2	Moderate		Light Solids		Musty		Grey
3	Serious						
4	Extreme		Heavy Solids		Septic		Black

3. a. Plant has _____ excellent good _____ fair _____ poor operation
 b. Plant has _____ excellent good _____ fair _____ poor maintenance
 c. Sand filters have _____ excellent good _____ fair _____ poor maintenance

d. Not operating at expected efficiency due to:

- (1) _____ hydraulic overload
 (2) _____ organic/ solids overload
 (3) _____ personnel inefficiency
 (4) _____ equipment failure
 (5) _____ wastes
 (6) _____

Disinfection: (Required May 1 thru Oct.31.)	
IN	OUT
<input checked="" type="checkbox"/>	_____ Chlorination Tablets
_____	_____ Dechlorination Tablets
_____	_____ U.V.

Yes No

4. _____ Compliance with NPDES Permit

Periodic Violations Y N Parameters: _____

Chronic Violations _____

5. Adequate plant safety

6. Operation and Maintenance Service Name Lynn Makeever

Frequency of Visits 1/week

Violation Date	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value
8/1/2006	001	00530	Total Suspended Solids	30D Conc	12	21.
8/22/2006	001	00530	Total Suspended Solids	7D Conc	18	21.
6/1/2008	001	31616	Fecal Coliform	30D Conc	1000	4520.
6/22/2008	001	31616	Fecal Coliform	7D Conc	2000	4520.
6/1/2007	001	00610	Nitrogen, Ammonia (NH3)	30D Conc	6.0	49.1
6/1/2007	001	00610	Nitrogen, Ammonia (NH3)	7D Conc	9.0	49.1
6/1/2007	001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.20	0.27877
6/1/2007	001	80082	CBOD 5 day	30D Conc	10	10.4
8/7/2007	001	50060	Chlorine, Total Residu	1D Conc	0.038	0.08
6/2/2007	001	31616	Fecal Coliform			AK