



State of Ohio Environmental Protection Agency

**Northwest District Office**

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
[www.epa.state.oh.us](http://www.epa.state.oh.us)

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Re: Notice of Violation  
Defiance County  
Sherwood WWTP  
NPDES Permit

March 11, 2009

Mayor and Council  
Village of Sherwood  
P.O. Box 4545  
Sherwood, Ohio 43527

Dear Mayor and Council:

On February 25, 2009 a compliance evaluation inspection of the Sherwood Wastewater Treatment Plant (WWTP) was conducted. Michelle McKeen, Industrial Fluid Management, was present and provided information concerning the operation and maintenance of the plant.

The average wastewater flow to this lagoon system is estimated to be 100,000 gallons per day. The facility is designed to accept up to 160,000 gallons per day. All major plant components were in operation at the time of the inspection. There was no record when the flow meter was last calibrated. The flow meter in the pump station should be calibrated annually. Barley straw was added to the lagoons in the summer to help improve treatment. We understand that village officials are investigating adding windmill aeration to the lagoons. There is no power available at the lagoon site. The effluent observed was clear and odorless.

A review of the facility's Discharge Monitoring Reports (DMR) for January 2008 through January 2009 showed that there have been numerous permit limit violations. The specific instances of noncompliance are attached on a separate sheet. Further review of your self-monitoring reports for the previous six months, ending in January 2009, indicates that you are in significant non-compliance (SNC) with the pH effluent limitation contained in your NPDES permit. The specific instance of SNC is attached on a separate sheet.

Please inform this office in writing as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in your Part III-General conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

The village continues to have issues with inflow and infiltration (I/I). A review of the village's NPDES permit schedule of compliance shows that the village was to complete a comprehensive sump pump inspection program, and submit a report of work performed to the Ohio EPA Northwest District Office by October 1, 2008. To this date no report has been received. Please respond in writing why the report has not been submitted. For future reference the second part of the compliance schedule states that the village is to complete a physical survey of the sanitary sewer collection system for the six phases recommended in the I/I report by June 1, 2010 and submit a report of work performed to the Ohio EPA Northwest District Office by July 1, 2010.

The completed compliance evaluation inspection report is enclosed. If there any questions please contact Ryan Gierhart at (419) 373-3053.

Sincerely,



Elizabeth A. Wick P.E.  
Water Quality Engineer  
Division of Surface Water

/llr

Enclosure

pc w/enclosure: Michelle McKeen, IFM  
[DSW, NWDO File 0001]

## NPDES Compliance Inspection Report

### Section A: National Data System Coding

Permit #	NPDES#	Month/Day/Year	Inspection Type	Inspector	Facility Type
2PA00017*HD	OH0020281	02/25/2009	C	S	1

### Section B: Facility Data

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Village of Sherwood WWTP	1:00 P.M.	July 1, 2007
	Exit Time	Permit Expiration Date
	1:45 P.M.	Jun 30, 2012
Name(s) and Title(s) of On-Site Representatives	Phone Number(s)	
Michelle McKeen	419-748-7438	
Name, Address and Title of Responsible Official	Phone Number	
Village of Sherwood P.O. Box 4545 Sherwood, Ohio 43527	419-782-8006	

### Section C: Areas Evaluated During Inspection

S = Satisfactory; M = Marginal; U = Unsatisfactory; N = Not Evaluated

S	Permit	S	Flow Measurement	N	Pretreatment
S	Records/Reports	S	Laboratory	S	Compliance Schedule
S	Operations & Maintenance	S	Effluent/Receiving Waters	S	Self-Monitoring Program
S	Facility Site Review	S	Sludge Storage/Disposal	N	Other
S	Collection System				

### Section D: Summary of Findings (Attach additional sheets if necessary)

Facility has been in significant non-compliance with PH. Alternatives are being investigated to improve treatment including the addition of windmill aerators and adding barley straw to the lagoons. Inflow and infiltration still appears to be a concern in the system with the pump station having overflows.

**Inspector**

**Reviewer**

<p style="text-align: center;"><i>Ryan Gierhart</i> Date: 3-10-09</p> <p>Ryan Gierhart Environmental Specialist II Division of Surface Water Northwest District Office</p>	<p style="text-align: center;"><i>Elizabeth A. Wick</i> Date: 3/9/09</p> <p>Elizabeth A. Wick, P.E. Water Quality Engineer Division of Surface Water Northwest District Office</p>
--	--

Sections E thru K: Complete on all inspections as appropriate

Permit #: Error! Reference source not found.  
NPDES #: Error! Reference source not found.

Y – Yes, N – No, N/A – Not Applicable, N/E – Not Evaluated

**Section E: Permit Verification**

Inspection observations verify the permit

- (a) Correct name and mailing address of permittee ..... Y
- (b) Correct name and location of receiving waters..... Y
- (c) Product(s) and production rates conform with permit application (Industries)..... N/A
- (d) Flows and loadings conform with NPDES permit..... Y
- (e) Treatment processes are as described in permit application... Y
- (f) New treatment process(es) added since last inspection..... N
- (g) Notification given to State of new, different or increased discharges..... Y
- (h) All discharges are permitted..... Y
- (i) Number and location of discharge points are as described in permit..... Y

Comments/Status:

**Section F: Compliance Schedules/Violations**

- (a) Any significant violations since the last inspection..... Y
- (b) Permittee is taking actions to resolve violations..... Y
- (c) Permittee has a compliance schedule..... Y
- (d) Compliance schedule contained in NPDES Permit # 2PA00017\*HD
- (e) Permittee is meeting compliance schedule..... Y

Comments/Status:

Permit #: Error! Reference source not found.  
 NPDES #: Error! Reference source not found.

**Section G: Operation & Maintenance**

**Treatment Works:**

Treatment facility properly operated and maintained

- (a) Standby power available.....generator  or dual feed ..... N/A
- (b) Adequate alarm system available for power or equipment failures.. Y
- (c) All treatment units in service other than backup units..... Y
- (d) Wastewater Treatment Works classification (OAC 3745-7)..... I
- (e) Operator of Record holds unexpired license of class required by permit..... Y  
 Class: I
- (f) Copy of certificate of Operator of Record displayed on-site..... N
- (g) Minimum operator staffing requirements fulfilled (OAC 3745-7)... Y
- (h) Routine and preventative maintenance scheduled/performed... Y
- (i) Any major equipment breakdown since last inspection..... Y
- (j) Operation and maintenance manual provided and maintained..... Y
- (k) Any plant bypasses since last inspection..... Y
- (l) Regulatory agency notified of bypasses..... Y  
 On MORs  and/or Spill Hotline (1-800-282-9378)
- (m) Any hydraulic and/or organic overloads since last inspection..... Y

**Record Keeping:**

- (a) Log book provided..... N
- (b) Format of log book (i.e. computer log, hard bound book)
- (c) Log book(s) kept onsite (in an area protected from weather)..... N
- (d) Log book contains the following:
  - I. Identification of treatment works..... N/E
  - II. Date/times of arrival/departure for Operator of Record and any other operator required by OAC 3745-7..... N/E
  - III. Daily record of operation and maintenance activities (including preventative maintenance, repairs and request for repairs)..... N/E
  - IV. Laboratory results (unless documented on bench sheets)... N/E
  - V. Identification of person making log entries..... N/E
- (d) Has the operator of record submitted written notification to the permittee, Ohio EPA and (if applicable) any local environmental agencies when a collection system overflow, treatment plant bypass or effluent limit violation has occurred..... Y

**Section G: Operation & Maintenance (con't)**

**Collection System:**

- (a) Percent combined system: %
- (b) Any collection system overflows since last inspection..... Y  
(CSO  and/or SSO )
- (c) Regulatory agency notified of overflows (SSOs)..... Y
- (d) CSO O&M plan provided and implemented..... Y
- (e) CSOs monitored and reported in accordance with permit..... Y
- (f) Portable pumps used to relieve system..... Y
- (g) Lift station alarms provided and maintained..... Y
- (h) Are lift stations equipped with permanent standby power  
or equivalent..... Y
- (i) Is there an inflow/infiltration problem (separate sewer system),  
or were there any major repairs to collection system since  
last inspection..... Y
- (j) Any complaints received since last inspection of basement flooding N
- (k) Are any portions of the sewer system at or near capacity..... N

Comments/Status:

The pump station had an overflow in January 2008. The. Log book should be kept onsite for review.

Permit #: Error! Reference source not found.  
NPDES #: Error! Reference source not found.

**Section H: Sludge Management**

- (a) Sludge management plan (SMP)  
Submitted date:                      Approval #:                      Not submitted     N/A
- (b) Sludge management plan current..... N/A  
(c) Sludge adequately disposed..... N/A  
(Method:                      )  
(d) If sludge is incinerated, where is ash disposed of  
(e) Is sludge disposal contracted..... N/A  
(Name:                      )  
(f) Has amount of sludge generated changed significantly since  
last inspection..... N/A  
(g) Adequate sludge storage provided at plant..... N/A  
(h) Land application sites monitored and inspected per SMP..... N/A  
(i) Records kept in accordance with State and Federal law..... N/A  
(j) Any complaints received in last year regarding sludge..... N/A  
(k) Is sludge adequately processed (digestion, pathogen control)..... N/A

**Comments/Status:**

Bacteria Solupacks are injected in the sludge at the bottom of the lagoons to help reduce the volume of sludge.

**Section I: Self-Monitoring Program**

**Flow Measurement:**

- (a) Primary flow measuring device operated and maintained..... Y  
Type of device: Ultrasonic & Parshall flume     Ultrasonic & Weir     Weir   
Calculated from influent     Other  (Specify:                      )
- (b) Calibration frequency adequate ..... Y  
(Date of last calibration:                      )  
(c) Secondary instruments operated and maintained..... Y  
(d) Flow measurement equipment adequate to handle full range  
of flows..... Y  
(e) Actual flow discharged is measured..... N  
(f) Flow measuring equipment inspection frequency  
 Daily     Weekly     monthly     other

**Comments/Status:**

Last Calibration of Flow meter was not known.

**Section I: Self-Monitoring Program (con't)**

**Sampling:**

- (a) Sampling location(s) are as specified by permit..... Y
- (b) Parameters and sampling frequency agree with permit..... Y
- (c) Permittee uses required sampling method..... Y
- (d) Sample collection procedures are adequate..... Y
  - (i) Samples refrigerated during compositing..... Y
  - (ii) Proper preservation techniques used..... Y
  - (iii) Containers and sample holding times prior to analysis conform with 40 CFR 136.3..... Y
- (e) Monitoring records (i.e., flow, pH, DO) maintained for a minimum of three years including all original strip chart recordings (i.e, continuous monitoring instrumentation, calibration and maintenance records)..... Y
- (f) Adequate records maintained of sampling date, time, location, etc.. Y

**Laboratory:**

*General*

- (a) EPA approved analytical testing procedures used (40 CFR 136.3).. Y
  - (b) If alternate analytical procedures are used, proper approval has been obtained..... Y
  - (c) Analyses being performed more frequently than required by permit. Y
  - (d) If (c) is yes, are results in permittee's self-monitoring report..... Y
  - (e) Commercial laboratory used..... Y
- Parameters analyzed by commercial lab: Low level Mercury, Grease,

**Metals**

Lab name: Alloway or Ginosko

*Quality Control/Quality Assurance*

- (f) Quality assurance manual provided and maintained..... Y
- (g) Satisfactory calibration and maintenance of instruments/equipment. Y
- (h) Adequate records maintained..... Y
- (i) Results of latest USEPA quality assurance performance sampling program:  Satisfactory  Marginal  Unsatisfactory

Date: 8/2009

**Comments/Status:**

Permit #: Error! Reference source not found.  
NPDES #: Error! Reference source not found.

**Section J: Effluent/Receiving Water Observations**

Outfall Number	Oil sheen	Grease	Turbidity	Visible Foam	Visible Floating Solids	Color	Other
001	no	no	no	no	no	clear	

**Comments/Status:**

Effluent was clear with no apparent odor.

**Section K: Multimedia Observations**

- (a) Are there indications of sloppy housekeeping or poor maintenance in work and storage areas or laboratories..... N
- (b) Do you notice staining or discoloration of soils, pavement or floors.. N
- (c) Do you notice distressed (unhealthy, discolored, dead) vegetation.. N
- (d) Do you see unidentified dark smoke or dust clouds coming from sources other than smokestacks..... N
- (e) Do you notice any unusual odors or strong chemical smells..... N
- (f) Do you see any open or unmarked drums, unsecured liquids, or damaged containment facilities..... N

If any of the above are observed, ask the following questions:

- (1) What is the cause of the condition?
- (2) Is the observed condition or source a waste product?
- (3) Where is the suspected contaminant normally disposed?
- (4) Is this disposal permitted?
- (5) How long has the condition existed and when did it begin?

**Comments/Status:**

Get New Data

Permit No.	Reporting Period	Station	Reporting Code	Parameter	Unit/Type	Limit	Reported Value	Violation Date
2PA00017*HD	January 2008	001	80082	CBOD 5 day	7D Qty	24	31.3534	1/8/2008
2PA00017*HD	February 2008	001	00610	Nitrogen, Ammonia (NH3)	30D Conc	9.1	10.55	2/1/2008
2PA00017*HD	March 2008	001	00610	Nitrogen, Ammonia (NH3)	30D Conc	9.1	9.87	3/1/2008
2PA00017*HD	March 2008	001	00610	Nitrogen, Ammonia (NH3)	30D Qty	5.5	7.21705	3/1/2008
2PA00017*HD	March 2008	001	80082	CBOD 5 day	30D Qty	15	15.5078	3/1/2008
2PA00017*HD	March 2008	001	00300	Dissolved Oxygen	1D Conc	5.0	3.8	3/5/2008
2PA00017*HD	March 2008	001	00610	Nitrogen, Ammonia (NH3)	7D Qty	8.3	11.3086	3/15/2008
2PA00017*HD	March 2008	001	80082	CBOD 5 day	7D Qty	24	26.6376	3/15/2008
2PA00017*HD	April 2008	001	00300	Dissolved Oxygen	1D Conc	5.0	3.3	4/22/2008
2PA00017*HD	May 2008	001	80082	CBOD 5 day	30D Conc	25	28.0375	5/1/2008
2PA00017*HD	May 2008	001	00400	pH	1D Conc	9.0	9.01	5/5/2008
2PA00017*HD	May 2008	001	00400	pH	1D Conc	9.0	9.17	5/7/2008
2PA00017*HD	May 2008	001	00400	pH	1D Conc	9.0	9.1	5/8/2008
2PA00017*HD	May 2008	001	00400	pH	1D Conc	9.0	9.03	5/9/2008
2PA00017*HD	May 2008	001	00400	pH	1D Conc	9.0	9.5	5/12/2008
2PA00017*HD	May 2008	001	00400	pH	1D Conc	9.0	9.61	5/13/2008
2PA00017*HD	May 2008	001	00400	pH	1D Conc	9.0	9.33	5/14/2008
2PA00017*HD	May 2008	001	00400	pH	1D Conc	9.0	9.48	5/15/2008
2PA00017*HD	May 2008	001	00400	pH	1D Conc	9.0	9.8	5/19/2008
2PA00017*HD	May 2008	001	00400	pH	1D Conc	9.0	10.03	5/27/2008
2PA00017*HD	May 2008	001	00400	pH	1D Conc	9.0	9.59	5/28/2008
2PA00017*HD	May 2008	001	00400	pH	1D Conc	9.0	9.61	5/29/2008
2PA00017*HD	May 2008	001	00400	pH	1D Conc	9.0	9.4	5/30/2008
2PA00017*HD	June 2008	001	31616	Fecal Coliform	30D Conc	1000	4591.89	6/1/2008
2PA00017*HD	June 2008	001	31616	Fecal Coliform	7D Conc	2000	60000.	6/1/2008
2PA00017*HD	June 2008	001	00400	pH	1D Conc	9.0	9.63	6/2/2008
2PA00017*HD	June 2008	001	00400	pH	1D Conc	9.0	9.21	6/3/2008
2PA00017*HD	June 2008	001	00400	pH	1D Conc	9.0	9.18	6/12/2008
2PA00017*HD	June 2008	001	00400	pH	1D Conc	9.0	9.13	6/13/2008
2PA00017*HD	June 2008	001	00400	pH	1D Conc	9.0	9.07	6/17/2008
2PA00017*HD	June 2008	001	31616	Fecal Coliform	7D Conc	2000	5200.	6/22/2008
2PA00017*HD	June 2008	001	00400	pH	1D Conc	9.0	9.03	6/24/2008
2PA00017*HD	June 2008	001	00400	pH	1D Conc	9.0	9.3	6/25/2008

2PA00017*HD	June 2008	001	00400	pH	1D Conc	9.0	9.17	6/26/2008
2PA00017*HD	June 2008	001	00400	pH	1D Conc	9.0	9.2	6/30/2008
2PA00017*HD	July 2008	001	00300	Dissolved Oxygen	1D Conc	5.0	4.53	7/3/2008
2PA00017*HD	July 2008	001	00400	pH	1D Conc	9.0	9.39	7/7/2008
2PA00017*HD	July 2008	001	00400	pH	1D Conc	9.0	9.29	7/8/2008
2PA00017*HD	July 2008	001	00400	pH	1D Conc	9.0	9.2	7/10/2008
2PA00017*HD	July 2008	001	00400	pH	1D Conc	9.0	9.14	7/11/2008
2PA00017*HD	July 2008	001	00400	pH	1D Conc	9.0	9.04	7/15/2008
2PA00017*HD	July 2008	001	00400	pH	1D Conc	9.0	9.49	7/16/2008
2PA00017*HD	July 2008	001	00400	pH	1D Conc	9.0	9.47	7/17/2008
2PA00017*HD	July 2008	001	00400	pH	1D Conc	9.0	9.45	7/18/2008
2PA00017*HD	July 2008	001	00400	pH	1D Conc	9.0	9.37	7/21/2008
2PA00017*HD	July 2008	001	31616	Fecal Coliform	7D Conc	2000	2150	7/22/2008
2PA00017*HD	July 2008	001	00400	pH	1D Conc	9.0	9.49	7/22/2008
2PA00017*HD	July 2008	001	00400	pH	1D Conc	9.0	9.55	7/23/2008
2PA00017*HD	July 2008	001	00400	pH	1D Conc	9.0	9.36	7/24/2008
2PA00017*HD	July 2008	001	00400	pH	1D Conc	9.0	9.41	7/25/2008
2PA00017*HD	July 2008	001	00400	pH	1D Conc	9.0	9.44	7/28/2008
2PA00017*HD	July 2008	001	00400	pH	1D Conc	9.0	9.63	7/29/2008
2PA00017*HD	July 2008	001	00400	pH	1D Conc	9.0	9.65	7/31/2008
2PA00017*HD	August 2008	001	00400	pH	1D Conc	9.0	9.64	8/1/2008
2PA00017*HD	August 2008	001	00400	pH	1D Conc	9.0	9.2	8/4/2008
2PA00017*HD	August 2008	001	00400	pH	1D Conc	9.0	9.63	8/5/2008
2PA00017*HD	August 2008	001	00400	pH	1D Conc	9.0	9.19	8/6/2008
2PA00017*HD	August 2008	001	00400	pH	1D Conc	9.0	9.58	8/7/2008
2PA00017*HD	August 2008	001	00400	pH	1D Conc	9.0	9.38	8/11/2008
2PA00017*HD	August 2008	001	00400	pH	1D Conc	9.0	9.4	8/12/2008
2PA00017*HD	August 2008	001	00400	pH	1D Conc	9.0	9.19	8/13/2008
2PA00017*HD	August 2008	001	00400	pH	1D Conc	9.0	9.08	8/14/2008
2PA00017*HD	August 2008	001	00400	pH	1D Conc	9.0	9.4	8/15/2008
2PA00017*HD	August 2008	001	00400	pH	1D Conc	9.0	9.11	8/18/2008
2PA00017*HD	August 2008	001	00400	pH	1D Conc	9.0	9.87	8/19/2008
2PA00017*HD	August 2008	001	00400	pH	1D Conc	9.0	9.6	8/20/2008
2PA00017*HD	August 2008	001	00400	pH	1D Conc	9.0	9.76	8/21/2008
2PA00017*HD	August 2008	001	00400	pH	1D Conc	9.0	9.61	8/22/2008
2PA00017*HD	August 2008	001	00400	pH	1D Conc	9.0	9.33	8/25/2008
2PA00017*HD	August 2008	001	00400	pH	1D Conc	9.0	9.17	8/26/2008

2PA00017*HD	August 2008	001	00400	pH	1D Conc	9.0	9.47	8/28/2008
2PA00017*HD	August 2008	001	00400	pH	1D Conc	9.0	9.87	8/29/2008
2PA00017*HD	September 2008	001	00400	pH	1D Conc	9.0	9.41	9/2/2008
2PA00017*HD	September 2008	001	00400	pH	1D Conc	9.0	9.27	9/3/2008
2PA00017*HD	September 2008	001	00400	pH	1D Conc	9.0	9.27	9/4/2008
2PA00017*HD	September 2008	001	00400	pH	1D Conc	9.0	9.17	9/5/2008
2PA00017*HD	September 2008	001	00400	pH	1D Conc	9.0	9.38	9/8/2008
2PA00017*HD	September 2008	001	00400	pH	1D Conc	9.0	9.29	9/9/2008
2PA00017*HD	September 2008	001	00400	pH	1D Conc	9.0	9.33	9/10/2008
2PA00017*HD	September 2008	001	00400	pH	1D Conc	9.0	9.27	9/11/2008
2PA00017*HD	September 2008	001	00400	pH	1D Conc	9.0	9.55	9/12/2008
2PA00017*HD	October 2008	001	00530	Total Suspended Solids	30D Conc	65	67.525	10/1/2008
2PA00017*HD	October 2008	001	00400	pH	1D Conc	9.0	9.07	10/7/2008
2PA00017*HD	October 2008	001	00400	pH	1D Conc	9.0	9.38	10/14/2008
2PA00017*HD	October 2008	001	00300	Dissolved Oxygen	1D Conc	5.0	3.7	10/15/2008
2PA00017*HD	October 2008	001	00400	pH	1D Conc	9.0	9.17	10/20/2008
2PA00017*HD	October 2008	001	00400	pH	1D Conc	9.0	9.03	10/21/2008
2PA00017*HD	October 2008	001	00400	pH	1D Conc	9.0	9.1	10/24/2008
2PA00017*HD	October 2008	001	00400	pH	1D Conc	9.0	9.01	10/27/2008
2PA00017*HD	October 2008	001	00400	pH	1D Conc	9.0	9.06	10/28/2008
2PA00017*HD	November 2008	001	00530	Total Suspended Solids	30D Conc	65	67.0125	11/1/2008
2PA00017*HD	November 2008	001	00400	pH	1D Conc	9.0	9.18	11/4/2008
2PA00017*HD	November 2008	001	00400	pH	1D Conc	9.0	9.38	11/6/2008
2PA00017*HD	November 2008	001	00400	pH	1D Conc	9.0	9.03	11/10/2008
2PA00017*HD	November 2008	001	00400	pH	1D Conc	9.0	9.9	11/12/2008
2PA00017*HD	November 2008	001	00400	pH	1D Conc	9.0	9.06	11/25/2008
2PA00017*HD	November 2008	001	00400	pH	1D Conc	9.0	9.01	11/28/2008
2PA00017*HD	December 2008	001	00400	pH	1D Conc	9.0	9.35	12/1/2008
2PA00017*HD	December 2008	001	00530	Total Suspended Solids	7D Qty	54	64.4218	12/8/2008
2PA00017*HD	December 2008	001	00400	pH	1D Conc	9.0	9.07	12/8/2008
2PA00017*HD	December 2008	001	00400	pH	1D Conc	9.0	9.05	12/10/2008

Get New  
Data

Get Detail  
for Selected  
Facility

### Facilities in Significant Non-Compliance \*\*

Period: Aug-08 Jan-09

County	Permit	Facility Name	Major	Station Code	Param Code	Parameter Name	Max Exceed	Months Signif Exceed (1)	# Months Exceed (2)
Defiance	2PA00017	Sherwood WWTP		1	00400	pH	10	0	5