

**Environmental
Protection Agency**

**Governor
Lt. Governor
Director**

July 29, 2011

RE: LAKE PARK TOOL
NPDES PERMIT NO: 3IS00020

Mr. Oscar Lund, President
Lake Park Tool and Machine, Inc.
1221 Velma Court
Youngstown, OH 44512

Dear Mr. Lund:

On June 21, 2011, we met to discuss the relocation of the discharge of contact cooling water. The discharge of cooling water was relocated into a storm water pond that was recently constructed for expansion of the building.

As we discussed, the NPDES Permit includes a description of the sampling location for compliance monitoring. The sample location description is as follows.

"At a point representative of the contact cooling water discharge located inside the southeast corner of the building"

The sampling description will be modified to specifically identify the pond discharge. In the interim, sampling for the process wastewater should be relocated to the pond discharge. In the event there is no discharge from the pond, "AL" should be placed in the upper left hand cell of the eDMR report. The code "AL" identifies to Ohio EPA that no discharge has occurred for the entire month. However, in the event that a discharge has occurred at any time during the month, a sample has to be collected and analyzed for the regulated parameters.


A review of the compliance record for Lake Park Tool was reviewed for the period covering June 2010 through May 2011. Of the six dates that discharge occurred, one violation was reported during the review period.

<u>Reporting Period</u>	<u>Parameter</u>	<u>Limit Type</u>	<u>Limit</u>	<u>Reported Value</u>	<u>Violation Date</u>
August 2010	pH	1-Day Conc.	6.5	5.27	8/12/2010

It appears that efforts to adjust the pH of the wastewater prior to discharge have been effective.

You may contact this office at (330) 963-1251 to discuss any questions you may have regarding this letter.

Respectfully,



John Kwolek
District Engineer
Division of Surface Water

JK:bo