



State of Ohio Environmental Protection Agency

Northeast District Office

Industrial
Plc
BPSite
54049
Chardon
Geauga
Chardon
Little Eagle

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korieski, Director

May 1, 2008

RE: GEAUGA COUNTY
11114 CHARDON ROAD
LITTLE EAGLE DRIVE-THRU
NPDES PERMIT NO. 3IG00055*DD

Mr. John A. Krizman, Owner
Little Eagle Drive-Thru
11114 Chardon Rd
Chardon, OH 44024

Dear Mr. Krizman:

On April 24, 2008, I inspected the wastewater plant serving your drive thru operating under the referenced NPDES permit.

The 1000-gallon plant was operating well on the day of my inspection, and it was operating as designed. The aeration tank had good color and good aeration. The sand filters had vegetation growing in the sand, and it should be removed. The effluent was clear, and apparently acceptable.

You have failed to submit required operating reports monthly as required by your permit. During the period commencing on October 1, 2007 to now, no reports have been received. You should provide a monthly operating report every month as required by your permit.

Please be advised that such instances of noncompliance may be cause for enforcement actions pursuant to the Ohio Revised Code, Chapter 6111. You must respond in writing by June 15, 2008, explaining corrective actions taken to correct this and to avoid repetition.

If there are any questions or comments regarding this notification, please contact me directly at (330) 963-1260.

Sincerely,

Douglas Hiestand
Environmental Engineer
Division of Surface Water

DH/mt

cc: Helen Hayes, Geauga County Health Department