



**Environmental  
Protection Agency**

Teo Strickland, Governor  
Lee Fisher, Lt. Governor  
Chris Korieski, Director

November 29, 2010

RE: WAYNE COUNTY  
ORRVILLE WATER TREATMENT PLANT  
NPDES # 3IW00090

Mr. Todd Fetty  
Superintendent  
Orrville Water Treatment Plant  
P.O. Box 107  
Orrville, Ohio 44667

Dear Mr. Fetty:

On November 18, 2010 this writer conducted an inspection of your facility. The purpose of the inspection was to gather information necessary to renew the above referenced NPDES permit. Your NPDES permit authorizes the discharge from outfalls 001 and 002. Outfall 001 is for filter backwash water. Outfall 002 is the discharge from the lime sludge lagoons located north of town across the street from the wastewater treatment plant.

At the time of the inspection, the lagoons and outfalls were in good condition. Both outfalls discharge to Little Chippewa Creek.

A review of your discharge monitoring reports (DMRs) covering the period January 2008 through October 2010 revealed the following effluent violations:

Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
September 2008	002	Total Suspended Solids	30D Conc	30	41.6	9/1/2008
May 2010	002	Total Suspended Solids	1D Conc	45	62.54	5/3/2010
May 2010	002	Total Suspended Solids	30D Conc	30	62.54	5/1/2010

The renewal NPDES permit for this facility will be public noticed in the near future. You will have 30 days from the date of public notice to submit written comments to Ohio EPA regarding the draft permit.

Overall, the results of the inspection were satisfactory. Should you have any questions or comments regarding this letter, please contact this office at (330) 963-1255.

Respectfully,

Todd Surrena  
Engineering Geologist  
Division of Surface Water

TMS/mt

cc: Wayne County Health Dept.

File: Industrial/Wayne/Orrville WTP