



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

March 16, 2009

RE: NORTH CANTON TRAVEL CENTER  
3IN00205\*CD  
STARK COUNTY

Mr. Marc Miles  
Store General Manager  
North Canto Travel Center  
4450 Portage Street NW  
North Canton, Ohio 44720

Dear Mr. Miles:

On March 13, 2009 this writer conducted a compliance evaluation of your outfalls for the North Canton Travel Center. At the time of the inspection it had not recently rained and there was no flow at outfalls 601, 001, and 002. The oil/water separator had a visual accumulation of floating oil on the surface of the water inside the tank. I met with you after inspection of the outfalls. We went over your records pertaining to the oil/water separator. Safety Klean is currently pumping the oil/water separator on a monthly basis. Our records do not indicate where the maintenance garage floor drains are routed. Please respond in writing to this office as to where these drains are routed.

A review of your compliance history as identified by our SWIMS tracking system identified the following violations for the time period of September 2007 through March 2009:

**Numeric Violations**

Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
601	Oil and Grease, Hexane	30D Conc	15	17.	9/1/2008
601	Oil and Grease, Hexane	30D Conc	15	20.	11/1/2008
601	Oil and Grease, Hexane	30D Conc	15	20.	10/1/2007

**Frequency Violations**

None

Our files do not include the non-compliance notifications that are required as outlined in Part III, Section 12 of the NPDES permit. This is a separate violation of your permit for each event.

If you should have any questions, feel free to contact this writer at (330) 963-1136.

Sincerely,

Philip P. Rhodes, P.E.  
Environmental Engineer  
Division of Surface Water

PPR/mt

File: Industrial Permit/Compliance

