



**Environmental
Protection Agency**

John Kasich, Governor
Robert F. Utz, Lt. Governor
Catherine E. Hanley, Director

April 23, 2010

RE: PRESSLER MEATS
COMPLIANCE INSPECTION
3IH00046
SUMMIT COUNTY

Mr. Roger Pressler
Pressler Home Dressed Meats
2553 Pressler Road
Akron, Ohio 44312

Dear Mr. Pressler:

On April 20, 2010 this writer conducted a compliance evaluation inspection of your facility. On this day the treatment plant appeared to be in good operation. The aeration chamber had a typical reddish brown color and was being properly aerated. The clarifier was covered with scum. The scum skimmer could not be seen as it was submerged or covered. The effluent weir also contained some solids. Collected material behind the inlet baffle to the clarifier was overflowing into the clarifier. The sand filter beds were clear and in good shape. Approximately 4 to 5 cubic yards of used filter sand has been piled next to the surface sand filters. This should be properly disposed. The effluent was clear and no visual problems were noted. Outfall 002 containing non-contact cooling water was also flowing clear.

Below you will find a summary of your NPDES permit compliance history for the time period of August 2008 through March 2010:

Numeric Violations

Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	Biochemical Oxygen Dem	30D Conc	10	12.	3/1/2010
001	Chlorine, Total Residu	1D Conc	0.038	.7	8/3/2009
001	Biochemical Oxygen Dem	30D Conc	10	13.	9/1/2009

Frequency Violations

None


For the March 2010 violation we received an e-mail from your operator as follows:

“I have communicated the operational problems at the plant with the owner. He and I have taken steps to resolve these issues.” I have relayed to him this is not an acceptable response to a violation. The level of detail as listed in Part III, Item, 12 of your NPDES permit is required.

Mr. Roger Pressler
Pressler Home Dressed Meats
April 23, 2010
Page 2

If you should have any questions concerning this letter, feel free to call this writer at (330) 963-1136.

Sincerely,

A handwritten signature in cursive script that reads "Phil Rhodes".

Philip P. Rhodes, P.E.
Environmental Specialist II
Division of Surface Water

PPR/mt

File: Industrial Permit\Compliance