



Environmental Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

June 1, 2011

RE: WAYNE COUNTY
QUALITYCASTINGS COMPANY
NPDES # 3IN00310

Mr. Steven Steiner
Safety and Environmental Coordinator
1200 North Main Street
Orrville, OH 44667

Dear Mr. Steiner:

On May 19, 2011, this writer conducted an NPDES inspection of the Quality Castings Company. You represented the facility during the inspection. The NPDES permit for your facility is for storm water and non-contact cooling water. Below are our findings from the inspection.

- 1) The stormceptors were found to be in satisfactory condition. You indicated that the stormceptors are pumped out approximately four or five times a year.
2) You indicated that Quality Castings Company has purchased two adjoining properties. These two properties will be included in the NPDES renewal permit. The two new outfalls will be identified as 004 and 005 and will be for storm water runoff.

A review of your Discharge Monitoring Reports (DMRs) covering the period January 2007 through April 2011 revealed the following effluent violations.

Table with 7 columns: Reporting Period, Station, Parameter, Limit Type, Limit, Reported Value, Violation Date. Contains 14 rows of violation data.

Mr. Steven Steiner
Quality Castings Company
May 31, 2011
Page 2

Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
August 2010	002	Total Suspended Solids	30D Conc	30	340	8/1/2010
August 2010	003	Total Suspended Solids	1D Conc	45	364	8/4/2010
August 2010	003	Total Suspended Solids	30D Conc	30	364	8/1/2010
August 2010	003	pH	1D Conc	6.5	6.16	8/4/2010
June 2009	002	Total Suspended Solids	1D Conc	45	52	6/1/2009
June 2009	002	Total Suspended Solids	30D Conc	30	52	6/1/2009
April 2011	002	Total Suspended Solids	1D Conc	45	108	4/4/2011
April 2011	002	Total Suspended Solids	30D Conc	30	108	4/1/2011

The renewal NPDES permit for this facility will be public noticed in the near future. You will have 30 days from the date of public notice to submit written comments to Ohio EPA regarding the draft permit.

Overall, the results of the inspection were satisfactory. Should you have any questions or comments regarding this letter, please contact this office at (330) 963-1255.

Respectfully,



Todd Surrena
Engineering Geologist
Division of Surface Water

TMS/mt

File: Industrial/Quality Casting Company