OhioEPA

State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 **FAX:** (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

November 20, 2007

RE: SKYLAND HILLS MOBILE HOME PARK
3IY00161 *BD
STARK COUNTY

Mr. Leonard Cooper, President
Skyland Hills Mobile Home Park
P.O. Box 36177
Canton, OH 44735

Dear Mr. Cooper:

On November 1, 2007, this writer conducted a compliance evaluation inspection of your facility for the purpose of determining compliance with the above referenced National Pollutant Discharge Elimination System (NPDES) permit. At the time of the inspection the following was noted:

1) Both sand filter halves need to be raked clean, leveled and the residuals removed.
2) There was no flow at the final discharge point.
3) No downstream accumulation of iron/manganese deposits could be seen for a distance of at least 50 feet.

Pictures were taken and are attached for your reference.

A review of your monthly operating reports for the time period of March 2007 through September 2007 by our compliance monitoring system revealed the following violations:

Numeric Violations

Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	Total Suspended Solids	30D Conc	30	90.	8/1/2007
001	Total Suspended Solids	1D Conc	45	90.	8/15/2007
001	Total Suspended Solids	30D Conc	30	101.	9/1/2007
001	Total Suspended Solids	1D Conc	45	101.	9/19/2007

We request that you provide a written response to address the above listed violations within 10 days of the receipt of this letter. The response should include an explanation for their occurrence and plans for returning to compliance as soon as possible. If you should have any questions concerning any of the above, feel free to contact this writer at (330) 963-1136.

Sincerely,

Philip P. Rhodes, P.E.
Environmental Engineer
Division of Surface Water

PPR/mt

attachments

File: Industrial/Permit Compliance

MHP WTP
filter 1
9.45