



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

June 23, 2009

RE: BULK STORAGE FACILITY
439 OAK STREET
BOARDMAN
NPDES PERMIT NO. 31100006

Ms. Monica Styles
Environmental Specialist
Sunoco Partners Marketing and Terminals
7155 Inkster Road
Taylor, MI 48180

Dear Ms. Styles:

On June 10, 2009, this writer conducted an unannounced Compliance Evaluation Inspection of the tank farm facility located at 439 Oak Street, Boardman, OH. The site is regulated by NPDES Permit No. 31100006*DD. The intent of the inspection was to evaluate the site and receiving stream for any impacts resulting from the discharge of storm water from the bulk storage area. It appears that the site has remained unchanged since the previous inspection on October 9, 2007.

The site was considered satisfactory at the time of the June 10, 2009 inspection. No impacts on the receiving stream were identified resulting from the discharge of storm water from the dike area.

A review of the monitoring data between May 2008 and June 2009 identified the following limit violation for the review period.

Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
May 2008	pH	1D Conc.	6.5	6.3	5/13/2008

You may contact this office at (330) 963-1251 to discuss any questions you may have.

Respectfully,

John Kwolek
District Engineer
Division of Surface Water

JK/mt

cc: Mark Whalen, Sun Pipeline

File: Industrial/Sun Pipeline Co./Permits and Compliance