



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

October 23, 2007

RE: SUNOCO PARTNERS  
MARKETING & TERMINALS  
439 OAK STREET  
NPDES PERMIT NO. 31100006

Ms. Monica Styles  
Environmental Specialist  
Sunoco Partners Marketing and Terminals  
7155 Inkster Road  
Taylor, MI 48180

Dear Ms. Styles:

On October 19, 2007, this writer conducted an unannounced Compliance Evaluation Inspection of the tank farm facility located at 439 Oak Street, Boardman, OH. The site is regulated by NPDES Permit No. 31100006\*CD. The intent of the inspection was to evaluate the site and receiving stream for any impacts resulting from the discharge of storm water from bulk storage area. It appears that the site has remained unchanged since the previous inspection on December 4, 2006.

The site was considered satisfactory at the time of the inspection. No impacts on the receiving stream were identified. A review of the monitoring data for the site identified no limit violations of the NPDES permit requirements. However, violations of the reporting requirements were identified for the following parameters.

Reporting Period	Violation Date	Station	Parameter	Sample Frequency	Expected	Reported
Nov 2006	11/1/2006	001	Carbon, Total Organic	1/Month	1	0
Dec 2006	12/1/2006	001	Phenol	1/Quarter	1	0
Dec 2006	12/1/2006	001	Carbon, Total Organic	1/Month	1	0
Jan 2007	1/1/2007	001	Carbon, Total Organic	1/Month	1	0
Feb 2007	2/1/2007	001	Carbon, Total Organic	1/Month	1	0
Mar 2007	3/1/2007	001	Carbon, Total Organic	1/Month	1	0
Apr 2007	4/1/2007	001	Carbon, Total Organic	1/Month	1	0

Be advised that Sunoco Pipeline must sample and report the results in accordance with the frequencies established in the NPDES permit. Failure to do so is a violation of the NPDES permit and a violation of Ohio Revised Code 6111.07. Revised reports must be submitted to Ohio EPA in the event the data is available.

You may contact this office at (330) 963-1251 to discuss any questions you may have.


Respectfully,

John Kwolek  
District Engineer  
Division of Surface Water

JK/mt

cc: Mark Whalen, Sun Pipeline

File: Industrial/Sun Pipeline Co./Permits and Compliance



Ohio EPA is an Equal Opportunity Employer