

**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korleski, Director

September 29, 2010

RE: TRAVELCENTERS OF AMERICA
SITE NO. 058
5400 SEVENTY-SIX DRIVE
NPDES PERMIT NO. 31N00333*AD

Mr. Dave Plummer
Environmental Associate
TravelCenters of America
24601 Center Ridge Road, Suite 200
Westlake, OH 44145-5634

Mr. Plummer:

On September 23, 2010, this writer conducted an unannounced inspection of the TravelCenters of America Site 058 located at 5400 Seventy-Six Drive, Youngstown, OH. The area had experienced an extended dry period prior to the inspection. The intent of the inspection was to evaluate the condition of the storm water system during the precipitation event. Mr. Victor Flowers represented the facility during the inspection.

Observations

The storm water pond and the receiving stream were in satisfactory condition at the time of the inspection. Because of the extended dry conditions, no storm water was being discharged from the basin at the time of the inspection. The condition of the water in the pond was satisfactory. No oil residue was apparent on the rip rap, no sheen was observed in the stream and no petroleum odor was apparent.


Compliance

Monitoring records for the facility were reviewed as part of this inspection to determine compliance with the NPDES Permit. The period of review was April 2009 through September 2010. Following is a list of limit violations identified over the review period.

Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
February 2010	Oil and Grease, Total	1-Day Conc.	10	13.	2/22/2010
February 2010	Oil and Grease, Total	30-Day Conc.	10	13.	2/1/2010

You may contact this office at (330) 963-1251 or at john.kwolek@epa.state.oh.us to discuss any questions you may have regarding this inspection report.

Respectfully,



John Kwolek
District Engineer
Division of Surface Water

JK/mt

cc: Ms. Mary Ault, General Manager, Travel Centers of America

File: Industrial/TravelCenter of America 058/Permits and Compliance

Northeast District Office
2110 East Aurora Road
Twinsburg, OH 44087-1924

330 | 963 1200
330 | 487 0769 (fax)
www.epa.ohio.gov