



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

January 23, 2008

RE: TRI COUNTY CONCRETE
3IN00128*BD 319*BD
SUMMIT COUNTY

Mr. Anthony Farinacci
President
Tri County Concrete
P.O. Box 665
Twinsburg, OH 44087

Dear Mr. Farinacci:

Our compliance evaluation system has identified your facility as being in noncompliance with the above referenced National Pollutant Discharge Elimination System (NPDES) Permit for the time period of February 2007 through November 2007:

Numeric Violations

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
002	00550	Oil and Grease, Total	30D Conc	10	80.	7/1/2007
002	00530	Total Suspended Solids	30D Conc	30	71.	8/1/2007
002	00530	Total Suspended Solids	1D Conc	45	71.	8/28/2007
001	00530	Total Suspended Solids	30D Conc	30	58.	9/1/2007
001	00530	Total Suspended Solids	1D Conc	45	58.	9/28/2007

Frequency Violations

Violation Date	Station	Reporting Code	Parameter	Sample Frequency	Expected	Reported
5/1/2007	002	00530	Total Suspended Solids	1/Month	1	0
5/1/2007	002	00400	pH	1/Month	1	0
5/1/2007	002	00550	Oil and Grease, Total	1/Month	1	0
5/1/2007	002	00056	Flow Rate	1/Month	1	0
5/1/2007	001	00530	Total Suspended Solids	1/Month	1	0
5/1/2007	001	00400	pH	1/Month	1	0
5/1/2007	001	00550	Oil and Grease, Total	1/Month	1	0
5/1/2007	001	00056	Flow Rate	1/Month	1	0
7/1/2007	001	00530	Total Suspended Solids	1/Month	1	0
7/1/2007	001	00400	pH	1/Month	1	0
7/1/2007	001	00550	Oil and Grease, Total	1/Month	1	0
7/1/2007	001	00056	Flow Rate	1/Month	1	0

Mr. Anthony Farinacci
Tri County Concrete
January 23, 2008
Page 2

In addition, our files do not contain noncompliance notifications as required in Part III, Section 12. This is considered a separate violation of your permit.

You are also in violation of the Schedule of Compliance listed in Part I, C, a of your NPDES Permit for failure to submit a complete and approvable permit-to-install application no later than December 1, 2007.

We request that you respond in writing to this office no later than January 31, 2008, with your intentions to resolve the above noncompliance. Failure to adequately respond may result in an enforcement action as allowed under Ohio Revised Code 6111. If you should have any questions concerning any of the above, feel free to contact this writer at (330) 963-1136.

Sincerely,

A handwritten signature in black ink that reads "Philip P. Rhodes". The signature is written in a cursive, flowing style.

Philip P. Rhodes, P. E.
Environmental Engineer
Division of Surface Water

PPR/mt