



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

February 24, 2009

RE: TROYERS TRAIL  
3IH00104\*FD  
HOLMES COUNTY

Mr. Ken Troyer  
Troyers Trail Bologna, Inc  
6552 State Route 515  
Dundee, Ohio 44624

Dear Mr. Troyer:

On February 18, 2009 this writer conducted a compliance evaluation inspection of your wastewater treatment facilities for the purpose of determining compliance with the above referenced NPDES permit. The following observations were made:

- 1) The sludge holding tank was properly aerated. There was a large amount of white foam nearly exiting the grating.
- 2) The aeration chamber was also properly aerated and was healthy chocolate brown in color.
- 3) The clarifier contained minor amounts of floating solids.
- 4) The sand filters were level and free of vegetation.
- 5) There was no discharge to the final outfall.

A review of your compliance history as identified by our SWIMS tracking system for the time period of September 2007 through July 2008 revealed the following violations:

Frequency

Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
601	Fecal Coliform			AK	9/9/2008

If you should have any questions, feel free to contact this writer at (330) 963-1136.

Sincerely,

Philip P. Rhodes P.E.  
Environmental Engineer  
Division of Surface Water

PPR/mt

File: Industrial Permit\Compliance