



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

April 13, 2011

RE: WALNUT CREEK WTP
NPDES PERMIT NO. 3IZ00041
2011 CEI

Mr. Kermit Miller, President
Walnut Creek Water Company
P.O. Box 29
Walnut Creek, OH 44687

Dear Mr. Miller:

On March 3, 2011, this writer conducted an unannounced inspection of the wastewater treatment system for the Walnut Creek WTP located on State Route 515. The intent of the inspection was to evaluate the condition of the treatment system. The compliance record for the plant was also reviewed for this inspection.

Observations:

The treatment system consists of a storage tank and red sand filters. The system is used to treat rejected wastewater from the water treatment system. There was no wastewater being treated at the time of the inspection. Wastewater in the storage tank was slightly turbid. The filters appeared to be in satisfactory condition.

Compliance Review:

A review of the compliance record was conducted as part of this inspection. The record of review was January 2010 through February 2011. One violation of the NPDES Permit was reported during the review period.

Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
June 2010	Chlorine, Free Availab	1D Conc	0.019	.05	6/1/2010

You may contact this writer at (330) 963-1251 to discuss any questions you may have regarding this inspection report.

Respectfully

John Kwolek
District Engineer
Division of Surface Water

JK:bo