



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Erie County
Milan Travel Park
Sewerage

October 26, 2007

Mr. Robert Schoen,
1740 N. County Road 29
Republic, OH 44867


Dear Mr. Schoen:

On September 20, 2007 an inspection was made of the Milan Travel Park wastewater treatment plant. In general, both operation and maintenance appeared fair. At the time of my visit, all major treatment components were in operation and a clear final effluent was observed being discharged to Mud Brook.

The sand filters contained some weeds and were in need of attention. Also, I was pleased to see disinfection and dechlorination tablets in the tube feeders. NPDES monthly operating reports are being received in a timely manner and indicate compliance with exception of a few bacteria violations thus far in 2007.

Our completed inspection report is enclosed. If you have any questions, please feel free to call me at (419) 373-3020, or email at rick.zuzik@epa.state.oh.us

Sincerely,



Richard A. Zuzik, MSE
Division of Surface Water

/lb

pc: ~~NWDO File~~
Dan Wood
Erie Co, Health Department

OHIO ENVIRONMENTAL PROTECTION AGENCY

OPERATION AND MAINTENANCE INSPECTION
WWTP'S LESS THAN 25,000 GPD

NPDES Permit No. 2PR00093

Facility Name Milan Travel Park Expiration Date 11-30-11
 Facility Address 11409 U.S. 250 Date 9-20-07 Time 11³⁵ (am) 1 pm
 City — County Erie Township Milan
 Name and Address of Owner Robert Schoen, 1740 N. Co. Rd 29, Republic OH
 Person Contacted None Owner Phone (419) 426-2085
 Flow: Design 15,000 GPD Present unknown GPD (metered - estimated)
 Trib. Pop. 107 sites (actual - estimated) Weather at time of inspection: Temp 80° Clear
 OEPA Personnel Rick Zwik District NWDO

1. Plant Effluent - Mark Severity No.

No.	Severity Description	No.	Turbidity	No.	Odor	No.	Color
<u>0</u>	None	<input checked="" type="checkbox"/>	Clear	<input checked="" type="checkbox"/>	None	<input checked="" type="checkbox"/>	Colorless
1	Mild						
2	Moderate		Light Solids		Musty		Grey
3	Serious						
4	Extreme		Heavy Solids		Septic		Black

2. Effect of effluent on Receiving Stream Name: Trib of Mud Brook

No.	Severity Description	No.	Turbidity	No.	Odor	No.	Color
<u>0</u>	None	<input checked="" type="checkbox"/>	Clear	<input checked="" type="checkbox"/>	None	<input checked="" type="checkbox"/>	Colorless
1	Mild						
2	Moderate		Light Solids		Musty		Grey
3	Serious						
4	Extreme		Heavy Solids		Septic		Black

3. a. Plant has _____ excellent _____ good ✓ fair _____ poor operation
 b. Plant has _____ excellent _____ good ✓ fair _____ poor maintenance
 c. Sand filters have _____ excellent _____ good ✓ fair _____ poor maintenance

d. Not operating at expected efficiency due to:

- (1) _____ hydraulic overload
 (2) _____ organic/ solids overload
 (3) _____ personnel inefficiency
 (4) _____ equipment failure
 (5) _____ wastes
 (6) _____

Disinfection: (Required May 1 thru Oct.31.)

<input checked="" type="checkbox"/> IN	<input type="checkbox"/> OUT	Chlorination Tablets
<input checked="" type="checkbox"/>	<input type="checkbox"/>	Dechlorination Tablets
<input type="checkbox"/>	<input type="checkbox"/>	U.V.

4. ✓ Yes — No Compliance with NPDES Permit

Periodic Violations Y N Parameters: bacteria
 Chronic Violations _____

5. ✓ Adequate plant safety

6. ✓ Operation and Maintenance Service Name Dan Wood

Frequency of Visits 1/WK

Facility Name: Milan Travel Park

Process	# Units	Unit	If Needed - Description and Comments
Preliminary	1	Trash Trap	Pumping Frequency:
		Grease Trap	Pumping Frequency:
		Bar Screen	
		Comminutor	
		Flow Equalization	
Aeration Equipment		Plant Timer. ___ Y. ___ N	Cycle Time:
	2	Motor/ Blower Unit	
Secondary Treatment	2	Aeration Tank	Color: <i>Choc. Brown</i> Adequate Aeration: Y. <input checked="" type="checkbox"/> N. <input type="checkbox"/>
Final Settling	1	Clarifier	<i>Clear</i>
	2	Sludge Return	In <input checked="" type="checkbox"/> Out
	1	Surface Skimmer	In <input checked="" type="checkbox"/> Out
		Fixed Media Clarifier	
Tertiary Treatment	2	Surface Sand Filter	<i>OK</i>
		Polishing Pond	
		Other	
Disinfection	1	Contact Tank	<i>pipe outlet to SF leaking</i>
	1	Chlorine Tube Feeder	
	1	Dechlorination Tube Feeder	
		Ultraviolet (UV)	
Flow Metering		Elapsed Pump Time	
		Recorder. (continuous total)	
Pumps	2	Raw Wastewater. (type)	
		Sand Filter. Effluent Dosing.	
Sludge Handling		Aerated Storage Tank	
		Sludge Drying Bed	
Sludge Disposal	1	Municipal POTW	
		Landfill	
		Land Application	
Advanced Treatment		Post Aeration	
		Spray Irrigation	
		Other	