



**Environmental  
Protection Agency**

Ted Strickland, Governor  
Lee Fisher, Lt. Governor  
Chris Korleski, Director

Re: Erie County  
Milan Travel Park  
NPDES Permit

August 24, 2010

Mr. Robert Schoen  
1740 N. County Road 29  
Republic, OH 44867

Dear Mr. Schoen:


On August 10, 2010, an inspection was made of the Milan Travel Park wastewater treatment plant. In general, both operation and maintenance appeared good. At the time of my visit, all major treatment components were in operation and a clear final effluent was observed being discharged to Mud Brook.

I was pleased to see disinfection and dechlorination tablets in the tube feeders. NPDES monthly discharge monitoring reports are being received in a timely manner and indicate compliance with exception of two violations thus far in 2010.

I'm disappointed to inform you that due to economic reasons the Erie County Commissioners have revised the long awaited U.S Route 250 sanitary sewer project to exclude serving the area south of Mason Road. They have informed us that they plan to include this area at a later date. Since your facility is the oldest in this area, it's important that it be operated and maintained as best as possible until the municipal sanitary sewer is extended.

Our completed inspection report is enclosed. If you have any questions, please call me at (419) 373-3020, or email at [rick.zuzik@epa.state.oh.us](mailto:rick.zuzik@epa.state.oh.us)

Sincerely,



Richard A. Zuzik, MSE  
Division of Surface Water

/lb

pc: ~~NWDO file~~  
Dan Wood  
Erie Co, Health Dept.

OHIO ENVIRONMENTAL PROTECTION AGENCY

OPERATION AND MAINTENANCE INSPECTION  
 WWTP'S LESS THAN 25,000 GPD

Facility Name Milan Travel Park NPDES Permit No. 2PR00093  
 Expiration Date 11-30-11  
 Facility Address 11404 U.S. 250 Date 8-10-10 Time 11:50 am (pm)  
 City \_\_\_\_\_ County Erie Township Milan  
 Name and Address of Owner Bob Schoen  
 Person Contacted \_\_\_\_\_ Owner Phone (419) 426-2085  
 Flow: Design 15,000 GPD Present \_\_\_\_\_ GPD (metered - estimated)  
 Trib. Pop. 107 sites (actual - estimated) Weather at time of inspection: Temp 85° Clear  
 OEPA Personnel Rick Zuzik District NWDO

1. Plant Effluent - Mark Severity No.

No.	Severity Description	No.	Turbidity	No.	Odor	No.	Color
<u>0</u>	None		Clear		None		Colorless
1	Mild						
2	Moderate		Light Solids		Musty		Grey
3	Serious						
4	Extreme		Heavy Solids		Septic		Black

2. Effect of effluent on Receiving Stream Name: Mud Brook

No.	Severity Description	No.	Turbidity	No.	Odor	No.	Color
<u>0</u>	None		Clear		None		Colorless
1	Mild						
2	Moderate		Light Solids		Musty		Grey
3	Serious						
4	Extreme		Heavy Solids		Septic		Black

3. a. Plant has \_\_\_\_\_ excellent ✓ good \_\_\_\_\_ fair \_\_\_\_\_ poor operation  
 b. Plant has \_\_\_\_\_ excellent ✓ good \_\_\_\_\_ fair \_\_\_\_\_ poor maintenance  
 c. Sand filters have \_\_\_\_\_ excellent ✓ good \_\_\_\_\_ fair \_\_\_\_\_ poor maintenance

d. Not operating at expected efficiency due to:

- (1) \_\_\_\_\_ hydraulic overload  
 (2) \_\_\_\_\_ organic/solids overload  
 (3) \_\_\_\_\_ personnel inefficiency  
 (4) \_\_\_\_\_ equipment failure  
 (5) \_\_\_\_\_ wastes  
 (6) \_\_\_\_\_

Disinfection: (Required May 1 thru Oct. 31)	
IN	OUT
<u>✓</u>	_____
_____	_____
_____	_____
	Chlorination Tablets
	Dechlorination Tablets
	Ultraviolet (U.V.)

Yes No ✓ (1/10 - 7/10)

4. \_\_\_\_\_ Compliance with NPDES Permit

Periodic Violations Y N Parameters: Bacteria, TSS

Chronic Violations \_\_\_\_\_

5. ✓ Adequate plant safety

6. ✓ Operation and Maintenance Service

Name Dan Wood

Frequency of Visits 1/wk

Facility Name: Milan Travel Park

Process	# Units	Unit	If Needed - Description and Comments
Preliminary	1	Trash Trap	Pumping Frequency
		Grease Trap	Pumping Frequency
		Bar Screen	
		Comminutor	
		Flow Equalization	
Aeration Equipment		Plant Timer ___Y ___N	Cycle Time:
	2	Motor / Blower Unit	
Secondary Treatment	2	Aeration Tank	Color: <u>Brown</u> Adequate Aeration Y <input checked="" type="checkbox"/> N
Final Settling	1	Clarifier	<u>good settling</u>
	1	Sludge Return	In <input checked="" type="checkbox"/> Out
	1	Surface Skimmer	In <input checked="" type="checkbox"/> Out
		Fixed Media Clarifier	
Tertiary Treatment	2	Surface-Sand Filter	
		Polishing Pond	
		Other	
Disinfection	1	Contact Tank	
	1	Chlorine Tube Feeder	<u>IN</u>
	1	Dechlorination Tube Feeder	<u>IN</u>
		Ultraviolet (UV)	
Flow Metering		Elapsed Pump Time	
		Recorder (continuous total)	
Pumps		Raw Wastewater (type)	
		Sand Filter Effluent Dosing	
Sludge Handling		Aerated Storage Tank	
		Sludge Drying Bed	
Sludge Disposal		Municipal POTW	
		Landfill	
		Land Application	
Advanced Treatment		Post Aeration	
		Spray Irrigation	
		Other	