



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Erie County
Strawberry Fields
Condominiums
NPDES Permit

August 18, 2009

Mr. Howard McGuire
Frances Group
13973 Gore Orphanage Road
Wakeman, Ohio 44889


Dear Mr. McGuire:

On July 29, 2009, an inspection was made of the sewerage facilities serving the Strawberry Fields Condominiums. At the time of my visit, I was disappointed to find the plant out of operation and totally septic. Your maintenance service was notified of the plant condition and later informed me that there was an electrical problem which has since been repaired.

I'm asking you to review the maintenance schedule with your operator to ensure adequate visits are made to prevent future operational problems. I will be making a follow up inspection in the near future to observe the plant under normal operating conditions.

If you have any questions, please call me at (419) 373-3020 or email at rick.zuzik@epa.state.oh.us.

Sincerely,



Richard A. Zuzik, MSE
Division of Surface Water

//lr

pc: Erie County Health Department
Eastwood Environmental
Ⓜ DSW: NWDO File