



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Erie County
Sunset Grill
NPDES Permit

July 24, 2008

Mr. Dan Decker, Owner
Sunset Grill
2812 Cleveland Road E
Huron, OH 44839

Dear Mr. Decker:

On June 12, 2008, an inspection was made of the wastewater treatment plant serving the Sunset Grill in conjunction with the renewal of your NPDES permit which expires August 31, 2008. As of this date we have yet to receive the renewal application forms, which were required to be submitted at least 6 months prior to the expiration date. Please find enclosed another set of forms, which should be completed and submitted as soon as possible. Please pay special attention to the signature requirements and applicable \$200.00 application fee payable to Treasurer – State of Ohio.

In general, both operation and maintenance was very poor. At the time of my visit, the plant was not running and you stated that you manually operated the plant intermittently. Effluent in the chlorine contact tank was grey and no disinfection was taking place. The surface sand filters were heavily weeded, and need to be cleaned.

A review of your file indicates noncompliance with permit limits in June 2007, and non submittal of monthly discharge monitoring reports since 2008. These are serious violations and place you in jeopardy of formal enforcement action from this agency.

We recently received notification that Eastwood Environmental has been retained to oversee operations of the plant, and hopefully bring the plant back into compliance.

You will be receiving a "draft" copy of the renewal permit for your review. Please read it carefully, as you will have a 30-day period in which to comment. Once issued as a final action, the permit will remain effective for another five year period.

If you have any questions, please feel free to call me at (419) 373-3020.

Sincerely,

Richard A. Zuzik, MSE
Division of Surface Water
/csl

pc: Erie County Health Department
Eastwood Environmental
DSW, NWDO file

Get New Data

Permit No.	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PR00085*BD	June 2006	001	31616	Fecal Coliform	30D Conc	1000	11300.	6/1/2006
2PR00085*BD	June 2006	001	31616	Fecal Coliform	7D Conc	2000	11300.	6/15/2006
2PR00085*BD	June 2007	001	00530	Total Suspended Solids	30D Conc	12	22.	6/1/2007
2PR00085*BD	June 2007	001	00530	Total Suspended Solids	7D Conc	18	22.	6/22/2007
2PR00085*BD	June 2007	001	00530	Total Suspended Solids	30D Qty	0.07	.12491	6/1/2007
2PR00085*BD	June 2007	001	00530	Total Suspended Solids	7D Qty	0.10	.12491	6/22/2007
2PR00085*BD	June 2007	001	00610	Nitrogen, Ammonia (NH)	30D Conc	2	10.6	6/1/2007
2PR00085*BD	June 2007	001	00610	Nitrogen, Ammonia (NH)	7D Conc	3	10.6	6/22/2007
2PR00085*BD	June 2007	001	00610	Nitrogen, Ammonia (NH)	30D Qty	0.01	.06018	6/1/2007
2PR00085*BD	June 2007	001	00610	Nitrogen, Ammonia (NH)	7D Qty	0.02	.06018	6/22/2007