



State of Ohio Environmental Protection Agency

**Northwest District Office**

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Re: Notice of Violation  
Fulton County  
Archbold WWTP  
Ohio EPA Permit No. 2PD00017  
NPDES Permit No. OH0020796

February 4, 2008

Mr. Frank D'Ambrosia  
WWTP Superintendent  
Village of Archbold  
P.O. box 406  
Archbold, Ohio 43502

Dear Mr. D'Ambrosia:

We are in receipt of your self-monitoring report covering the months of October 2007, through December 2007, for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance are attached on a separate sheet. Further review of your self-monitoring reports for the previous six months, ending in December 2007, indicates that you are in significant non-compliance (SNC) with an effluent limitation contained in your NPDES permit. The specific instance of SNC is attached on a separate sheet.

Please inform this office in writing as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in your Part III-General conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner.

Mr. Frank D'Ambrosia  
February 4, 2008  
Page 2

You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets or U. S. EPA's "*Facility Pollution Prevention Guide*" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614)644-3469.

If there are any questions, please contact me at (419) 373-3022.

Sincerely,



Elizabeth A. Wick, P.E.  
District Engineer/Unit Supervisor  
Division of Surface Water

/lr

Enclosure

~~pc:w/Enclosure: DSW-NWDO.File~~



Violations for Archbold WWT P - October thru December 2007

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PD00017*ID	October 2007	002	50060	Chlorine, Total Residu	1D Conc	0.02	.16	10/1/2007
2PD00017*ID	October 2007	002	50060	Chlorine, Total Residu	1D Conc	0.02	.05	10/5/2007
2PD00017*ID	October 2007	002	50060	Chlorine, Total Residu	1D Conc	0.02	.59	10/18/2007
2PD00017*ID	October 2007	002	50060	Chlorine, Total Residu	1D Conc	0.02	.07	10/31/2007
2PD00017*ID	October 2007	002	61942	pH, Minimum	1D Conc	6.5	6.38	10/22/2007
2PD00017*ID	November 2007	002	61941	pH, Maximum	1D Conc	9.0	9.32	11/17/2007
2PD00017*ID	November 2007	002	61942	pH, Minimum	1D Conc	6.5	6.46	11/2/2007
2PD00017*ID	November 2007	002	61942	pH, Minimum	1D Conc	6.5	6.46	11/12/2007
2PD00017*ID	December 2007	002	00300	Dissolved Oxygen	1D Conc	5.3	4.7	12/6/2007
2PD00017*ID	December 2007	002	00300	Dissolved Oxygen	1D Conc	5.3	3.1	12/12/2007
2PD00017*ID	December 2007	002	00300	Dissolved Oxygen	1D Conc	5.3	5.	12/13/2007

Get New Data

Get Detail for Selected Permit

### Facilities in Significant Non-Compliance \*\*

Period: Jul-07 Dec-07

County	Permit #	Facility Name	Major	Station Code	Param Code	Parameter Name	Max % Exceed	# Months Signif Exceed (1)**	# Months Exceed (2)**
Fulton	2PD00017	Archbold WWTP	M	2	50060	Chlorine, Total Residual	2850	2	2