



Environmental  
Protection Agency

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

Re: Fulton County  
Village of Archbold  
NPDES Permit

June 10, 2011

Mr. Frank D'Ambrosia, Superintendent  
Village of Archbold  
P. O. Box 406  
Archbold, Ohio 43502

Dear Mr. D'Ambrosia:

On May 31, 2011, I conducted an inspection of the Archbold Wastewater Treatment Plant. You were present and provided information concerning the operation and maintenance of the treatment facilities.

At the time of inspection, all required treatment processes and associated equipment were in operation. The discharge to Brush Creek was clear with no noticeable odor. The wastewater treatment plant and the surrounding grounds were well maintained.

A review of the Discharge Monitoring Reports (DMR) from January 2011 to May 2011 shows that there have been a couple permit limit violations at the facility. The specific instances of noncompliance are enclosed on a separate sheet. It was noted that the loading violation was due to increased flow to the plant from the heavy rains during the month of April.

If there are any questions please contact me at (419) 373-3053.

Sincerely,

Ryan Gierhart  
Division of Surface Water

/cs

Enclosure

pc: Mayor and Council

~~NWDO--DSW:File~~

Get New Data

| Permit No.  | Reporting Period | Station | Reporting Code | Parameter              | Limit Type | Limit | Reported Value | Violation Date |
|-------------|------------------|---------|----------------|------------------------|------------|-------|----------------|----------------|
| 2PD00017*KD | January 2011     | 002     | 00530          | Total Suspended Solids | 7D Conc    | 36.9  | 41.25          | 1/1/2011       |
| 2PD00017*KD | April 2011       | 002     | 80082          | CBOD 5 day             | 7D Qty     | 308   | 372.001        | 4/22/2011      |