



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

RE: Notice of Violation
Fulton County
Camelot South Estate MHP
Ohio EPA Permit No. 2PY00038
NPDES Permit No. OH0126772

December 5, 2007

Mr. Richard Goldsmith
Owner
Camelot South Estate MHP
8037 C.R. 14
Wauseon, OH 43567

Dear Mr. Goldsmith:

We are in receipt of your self-monitoring report covering the months of July 2007 through September 2007 for the referenced facility. Our review indicates a violation of the conditions of your NPDES permit. The specific instances of noncompliance are attached on a separate sheet.

Please inform this office in writing as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in your Part III-General conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets or U. S. EPA's "Facility Pollution Prevention Guide" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614)644-3469.

If there are any questions, please contact me at (419) 373-3022.

Sincerely,

Justin A. Williams
Division of Surface Water

lb

Enclosure

Pc w/Enclosure: ~~NWDD File~~
Mr. Dave Pike

Get New Data

Violations for Camelot South Estates MHP - July thru September 2007

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PY00038*AD	July 2007	001	00300	Dissolved Oxygen	1D Conc	6.0	.01	7/5/2007
2PY00038*AD	July 2007	001	00300	Dissolved Oxygen	1D Conc	6.0	2.2	7/11/2007
2PY00038*AD	July 2007	001	00300	Dissolved Oxygen	1D Conc	6.0	3.6	7/18/2007
2PY00038*AD	July 2007	001	00300	Dissolved Oxygen	1D Conc	6.0	3.9	7/25/2007
2PY00038*AD	August 2007	001	00300	Dissolved Oxygen	1D Conc	6.0	4.2	8/1/2007
2PY00038*AD	August 2007	001	00300	Dissolved Oxygen	1D Conc	6.0	4.2	8/9/2007
2PY00038*AD	August 2007	001	00400	pH	1D Conc	6.5	5.8	8/17/2007
2PY00038*AD	August 2007	001	00300	Dissolved Oxygen	1D Conc	6.0	4.7	8/17/2007
2PY00038*AD	August 2007	001	00400	pH	1D Conc	6.5	6.4	8/28/2007
2PY00038*AD	August 2007	001	00300	Dissolved Oxygen	1D Conc	6.0	2.7	8/28/2007
2PY00038*AD	September 2007	001	00300	Dissolved Oxygen	1D Conc	6.0	4.6	9/5/2007
2PY00038*AD	September 2007	001	00300	Dissolved Oxygen	1D Conc	6.0	4.5	9/11/2007
2PY00038*AD	September 2007	001	00300	Dissolved Oxygen	1D Conc	6.0	3.6	9/26/2007

Permit No	Reporting Period	Violation		Reporting Code	Parameter	Sample		
		Date	Station			Frequency	Expected	Reported
2PY00038*AD	July 2007	7/8/2007	001	00400	pH	1/Week	1	0
2PY00038*AD	July 2007	7/22/2007	001	00400	pH	1/Week	1	0
2PY00038*AD	August 2007	8/8/2007	001	00400	pH	1/Week	1	0
2PY00038*AD	September 2007	9/8/2007	001	00400	pH	1/Week	1	0
2PY00038*AD	September 2007	9/22/2007	001	00400	pH	1/Week	1	0