



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Notice of Violation
Fulton County
Camelot South Estate MHP
Ohio EPA Permit No. 2PY00038
NPDES Permit No. OH0126772

November 14, 2008

Mr. Richard Goldsmith, Owner
Camelot South Estate MHP
8037 County Road 14
Wauseon, Ohio 43567

Dear Mr. Goldsmith:

We are in receipt of your self-monitoring report covering the months of April 2008, through September 2008, for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance are attached on separate sheets.

This letter again serves as notice of violation for failure to submit a Permit to Install (PTI) application and detail plans for upgrades to your wastewater treatment plant. The PTI and detail plans were due April 1, 2008. In our letter dated July 23, 2008, we requested that the detail plans be submitted within 30 days of the date of that letter. To the date of this letter we have not received a PTI application and detail plans for your facility. **Within 30 days** of the date of this letter, submit a PTI application and detail plans for wastewater treatment upgrades to meet the final limits contained in your NPDES permit. Failure to meet this date will result in our Office recommending enforcement actions be taken by the Director to bring your facility into compliance with its NPDES permit.

Please inform this office in writing as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.


Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in your Part III-General conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

Mr. Richard Goldsmith, Owner
November 14, 2008
Page 2

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets or U. S. EPA's "*Facility Pollution Prevention Guide*" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614)644-3469.

If there are any questions, please contact me at (419) 373 – 3022.

Sincerely,




Justin A. Williams

Division of Surface Water

/llr

Enclosure

~~Pc w/Enclosure: DSW-NWDO File~~
Mr. Dave Pike



Camelot South Estates MHP July-September 2008 Violations

Param No	Reporting Period	Station	Reporting Code	Parameter	Unit	Limit	Reported Value	Violation Date
2PY00038*AD	July 2008	001	00400	pH	1D Conc	6.5	4.4	7/23/2008
2PY00038*AD	August 2008	001	00300	Dissolved Oxygen	1D Conc	6.0	5.2	8/6/2008
2PY00038*AD	August 2008	001	00400	pH	1D Conc	6.5	5.7	8/13/2008
2PY00038*AD	August 2008	001	00400	pH	1D Conc	6.5	4.5	8/20/2008
2PY00038*AD	August 2008	001	00300	Dissolved Oxygen	1D Conc	6.0	4.2	8/20/2008
2PY00038*AD	August 2008	001	00400	pH	1D Conc	6.5	4.5	8/27/2008
2PY00038*AD	August 2008	001	00300	Dissolved Oxygen	1D Conc	6.0	4.2	8/27/2008
2PY00038*AD	September 2008	001	00300	Dissolved Oxygen	1D Conc	6.0	2.9	9/5/2008
2PY00038*AD	September 2008	001	00400	pH	1D Conc	6.5	4.7	9/11/2008
2PY00038*AD	September 2008	001	00400	pH	1D Conc	6.5	4.6	9/17/2008
2PY00038*AD	September 2008	001	00400	pH	1D Conc	6.5	4.7	9/24/2008
2PY00038*AD	September 2008	001	00300	Dissolved Oxygen	1D Conc	6.0	5.	9/24/2008