



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

RE: Notice of Violation
Fulton County
Camelot South Estate MHP
Ohio EPA Permit No. 2PY00038
NPDES Permit No. OH0126772

March 5, 2009

Mr. Richard Goldsmith
Owner
Camelot South Estate MHP
8037 C.R. 14
Wauseon, OH 43567

Dear Mr. Goldsmith:

We are in receipt of your self-monitoring report covering the months of October 2008 through December 2008 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance are attached on separate a sheet.

This letter serves as a third notice of violation for failure to submit a Permit to Install (PTI) application and detail plans for upgrades to your wastewater treatment plant. The PTI and detail plans were due April 1, 2008. In our letter dated July 23, 2008 we requested that the detail plans be submitted within 30 days of the date of that letter. In our letter dated November 14, 2008 we again requested that the detail plans be submitted within 30 days of the date of that letter and we stated that failure to meet this date would result in our office recommending enforcement action be taken by the Director to bring your facility into compliance with its NPDES permit. To the date of this letter we have not received a PTI application and detail plans for your facility. Therefore, our office will be recommending enforcement action be taken by the Director to bring your facility into compliance with its NPDES permit.

Please inform this office in writing as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.


The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention,

Mr. Richard Goldsmith
March 5, 2009
Page Two

including fact sheets or U. S. EPA's "*Facility Pollution Prevention Guide*" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614)644-3469.

If there are any questions, please contact me at (419) 373 – 3022.

Sincerely



Justin A. Williams
Division of Surface Water

/lb

Enclosure

Pc w/Enclosure:

~~NWDO-DSW File~~
Mr. Dave Pike

Get New Data

Carmelot South Estates MHP violations for October-December 2008

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PY00038*AD	October 2008	001	00400	pH	1D Conc	6.5	4.5	10/1/2008
2PY00038*AD	October 2008	001	00400	pH	1D Conc	6.5	4.2	10/8/2008
2PY00038*AD	October 2008	001	00300	Dissolved Oxygen	1D Conc	6.0	3.4	10/15/2008
2PY00038*AD	November 2008	001	00400	pH	1D Conc	6.5	6.	11/6/2008
2PY00038*AD	November 2008	001	00300	Dissolved Oxygen	1D Conc	6.0	3.3	11/12/2008
2PY00038*AD	November 2008	001	00300	Dissolved Oxygen	1D Conc	6.0	3.5	11/19/2008
2PY00038*AD	November 2008	001	00300	Dissolved Oxygen	1D Conc	6.0	3.1	11/26/2008
2PY00038*AD	December 2008	001	00300	Dissolved Oxygen	1D Conc	6.0	5.1	12/3/2008
2PY00038*AD	December 2008	001	00300	Dissolved Oxygen	1D Conc	6.0	5.2	12/10/2008
2PY00038*AD	December 2008	001	00300	Dissolved Oxygen	1D Conc	6.0	4.1	12/17/2008
2PY00038*AD	December 2008	001	00300	Dissolved Oxygen	1D Conc	6.0	5.6	12/26/2008