



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

RE: Notice of Violation
Fulton County
Camelot South Estate MHP
Ohio EPA Permit No. 2PY00038
NPDES Permit No. OH0126772

August 17, 2009

Mr. Richard Goldsmith
Camelot South Estate MHP
8037 County Road 14
Wauseon, Ohio 43567

Dear Mr. Goldsmith:

We are in receipt of your self-monitoring report covering the months of April through June 2009 for the referenced facility. Our review indicates a violation of the conditions of your NPDES permit. The specific instance of noncompliance is attached on separate a sheet.

This letter serves as a fifth notice of violation for failure to submit a Permit to Install (PTI) application and detail plans for upgrades to your wastewater treatment plant. The PTI and detail plans were due April 1, 2008. We have received your letter dated June 30, 2009 indicating that you have contacted a consultant to design upgrades to your WWTP.


Please inform this office in writing as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets or U. S. EPA's "Facility Pollution Prevention Guide" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614)644-3469.

Mr. Richard Goldsmith
August 17, 2009
Page 2

If there are any questions, please contact me at (419) 373-3022.

Sincerely,



Justin A. Williams
Division of Surface Water

/csi

Enclosure

Pc w/Enclosure: NWDO – DSW File :
Mr. Dave Pike

Get New Data

Violation for Camelot South MHP - April - June 2009

Permit No.	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PY00038*AD	May 2009	001	00300	Dissolved Oxygen	1D Conc	6.0	4.5	5/1/2009