



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

RE: Notice of Violation
Fulton County
Delta WWTP
Ohio EPA Permit No. 2PB00003
NPDES Permit No. OH0020974
and
Delta WTP
Ohio EPA Permit No. 2IW00070
NPDES Permit No. OH0041823

February 6, 2008

Mr. Larry Born
WWTP & WTP Superintendent
Village of Delta
401 Main Street
Delta, OH 43515

Dear Mr. Born:

We are in receipt of your self-monitoring reports covering the months of October 2007 through December 2007 for the above referenced permits. Our review indicates violations of the conditions of your NPDES permits. The specific instances of noncompliance are attached on separate sheets. Further review of your self-monitoring reports for the previous six months, ending in December 2007, for the Delta WWTP indicates that you are in significant non-compliance (SNC) with several effluent limitations contained in your NPDES permit. The specific instance of SNC are attached on a separate sheet.


Please inform this office in writing as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in your Part III-General conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

Mr. Larry Born
February 6, 2008
Page 2

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets or U. S. EPA's "*Facility Pollution Prevention Guide*" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614)644-3469. If there are any questions, please contact me at (419) 373-3022.

Sincerely,


Justin A. Williams
Division of Surface Water

/cs1

Enclosure

Pc: w/Enclosure: NWDO File (2) :

Get New Data

Violations for Delta WTP - October thru December 2007

Permit No.	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2IW00070*GD	October 2007	001	00530	Total Suspended Solids 1D Conc	18	23.	23.	10/3/2007
2IW00070*GD	October 2007	001	00530	Total Suspended Solids 30D Conc	12	23.	23.	10/1/2007