



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

RE: Notice of Violation
Fulton County
Fayette WWTP
Ohio EPA Permit No. 2PB00045
NPDES Permit No. OH0025127

November 14, 2008

Mr. Bob Seigneur
WWTP Superintendent
Village of Fayette
P.O. Box 87
Fayette, OH 43524

Dear Mr. Seigneur:

We are in receipt of your self-monitoring reports covering the months of April 2008 through September 2008 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance are attached on a separate sheet. As a reminder, use the "AC" code, as needed for each parameter, for the days of the month that there is no discharge. If there is no discharge the entire month, use the "AL" code.

Please inform this office in writing as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in your Part III-General conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets or U. S. EPA's "Facility Pollution Prevention Guide" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614)644-3469.

If there are any questions, please contact me at (419) 373 - 3022.

Sincerely,

Justin A. Williams
Division of Surface Water
/lb

Enclosure

~~Pc.w/Enclosure: NWDO - DSW File~~

Get New Data

Fayette WWT P April - June 2008 Violations

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PB00045*GD	May 2008	001	00530	Total Suspended Solids	30D Conc	65	71.	5/1/2008
2PB00045*GD	June 2008	001	31616	Fecal Coliform	30D Conc	1000	1600.	6/1/2008

Get New Data

Fayette LUUP July - September 2008 Violations

Permit No.	Reporting Period	Station	Reporting Code	Parameter	Sample Frequency	Expected	Reported	Violation Date
2PB00045*GD	July 2008	601	00530	Total Suspended Solids	2/Week	2	1	07/22/2008
2PB00045*GD	July 2008	601	80082	CBOD 5 day	2/Week	2	1	07/22/2008
2PB00045*GD	July 2008	601	00400	pH	1/Day	1	0	07/02/2008
2PB00045*GD	July 2008	601	00400	pH	1/Day	1	0	07/03/2008
2PB00045*GD	July 2008	601	00400	pH	1/Day	1	0	07/04/2008
2PB00045*GD	July 2008	601	00400	pH	1/Day	1	0	07/05/2008
2PB00045*GD	July 2008	601	00400	pH	1/Day	1	0	07/06/2008
2PB00045*GD	July 2008	601	00400	pH	1/Day	1	0	07/09/2008
2PB00045*GD	July 2008	601	00400	pH	1/Day	1	0	07/10/2008
2PB00045*GD	July 2008	601	00400	pH	1/Day	1	0	07/11/2008
2PB00045*GD	July 2008	601	00400	pH	1/Day	1	0	07/12/2008
2PB00045*GD	July 2008	601	00400	pH	1/Day	1	0	07/13/2008
2PB00045*GD	July 2008	601	00400	pH	1/Day	1	0	07/16/2008
2PB00045*GD	July 2008	601	00400	pH	1/Day	1	0	07/17/2008
2PB00045*GD	July 2008	601	00400	pH	1/Day	1	0	07/18/2008
2PB00045*GD	July 2008	601	00400	pH	1/Day	1	0	07/19/2008
2PB00045*GD	July 2008	601	00400	pH	1/Day	1	0	07/20/2008
2PB00045*GD	July 2008	601	00400	pH	1/Day	1	0	07/23/2008
2PB00045*GD	July 2008	601	00400	pH	1/Day	1	0	07/24/2008
2PB00045*GD	July 2008	601	00400	pH	1/Day	1	0	07/25/2008
2PB00045*GD	July 2008	601	00400	pH	1/Day	1	0	07/26/2008
2PB00045*GD	July 2008	601	00400	pH	1/Day	1	0	07/27/2008
2PB00045*GD	July 2008	601	00400	pH	1/Day	1	0	07/28/2008
2PB00045*GD	July 2008	601	00400	pH	1/Day	1	0	07/30/2008
2PB00045*GD	July 2008	601	00400	pH	1/Day	1	0	07/31/2008
2PB00045*GD	September 2008	001	00530	Total Suspended Solids	2/Week	2	0	09/01/2008
2PB00045*GD	September 2008	001	00530	Total Suspended Solids	2/Week	2	0	09/15/2008
2PB00045*GD	September 2008	001	00530	Total Suspended Solids	2/Week	2	0	09/22/2008
2PB00045*GD	September 2008	001	00610	Nitrogen, Ammonia (NH3)	1/2Weeks	1	0	09/15/2008
2PB00045*GD	September 2008	001	31616	Fecal Coliform	2/Week	2	0	09/01/2008
2PB00045*GD	September 2008	001	31616	Fecal Coliform	2/Week	2	0	09/15/2008
2PB00045*GD	September 2008	001	31616	Fecal Coliform	2/Week	2	0	09/22/2008
2PB00045*GD	September 2008	001	80082	CBOD 5 day	2/Week	2	0	09/01/2008

2PB00045*GD	September 2008	001	80082	CBOD 5 day	2/Week	2	0	09/15/2008
2PB00045*GD	September 2008	001	80082	CBOD 5 day	2/Week	2	0	09/22/2008