



State of Ohio Environmental Protection Agency

**Northwest District Office**

347 North Dunbridge Rd.  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.ohio.gov

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Re: Notice of Violation  
Fulton County  
Village of Fayette  
NPDES Permit

November 2, 2010

Mr. Bob Seigneur, WWTP Superintendent  
Village of Fayette  
P. O. Box 87  
Fayette, Ohio 43521

Dear Mr. Seigneur:

On October 27, 2010, I conducted an inspection at the wastewater treatment facility serving the Village of Fayette. The facility is located on the north side of County Road S, between State Route 66 and County Road 23, Gorham Township. You were present and provided operation and maintenance information. There was no discharge during the inspection. Our observations can be found on the enclosed inspection report.

A review of the discharge monitoring reports (DMRs) from March 2010, to September 2010, shows that there have been numerous NPDES permit limit violations. The specific instances of noncompliance are attached on a separate sheet. Further review of your self-monitoring reports for the previous six months, ending in September 2010, indicates that you are in significant non-compliance (SNC) with effluent limitations contained in your NPDES permit. The specific instances of SNC are attached on a separate sheet. Please inform this office in writing as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

If you have any questions or comments please contact me at (419) 373-3053.

Sincerely,

Ryan Gierhart  
Division of Surface Water

//lr

Enclosure

pc w/enclosure: Mayor and Council  
DSW-NWDO File



State of Ohio Environmental Protection Agency  
Northwest District Office

## NPDES Compliance Inspection Report

Section A: National Data System Coding					
Permit #	NPDES#	Month/Day/Year	Inspection Type	Inspector	Facility Type
2PB00045	OH0025127	10/27/10	C	S	1

Section B: Facility Data		
Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Village of Fayette WWTP North side of C.R. S, between S.R. 66 & C.R. 23 Fayette, OH 43521	11:30 am	July 1, 2007
	Exit Time	Permit Expiration Date
	12:00 pm	June 30, 2012
Name(s) and Title(s) of On-Site Representatives	Phone Number(s)	
Bob Signeur – Wastewater Superintendent	(419) 237 – 3215	
Name, Address and Title of Responsible Official	Phone Number	
Mayor & Council Village of Fayette 125 W. Mail St. P.O. Box 87 Fayette, OH 43521	(419) 237 – 2116	

Section C: Areas Evaluated During Inspection					
(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)					
S	Permit	N	Flow Measurement	N	Pretreatment
N	Records/Reports	N	Laboratory	S	Compliance Schedule
S	Operations & Maintenance	N	Effluent/Receiving Waters	S	Self-Monitoring Program
S	Facility Site Review	N	Sludge Storage/Disposal	N	Other
N	Collection System				

Section D: Summary of Findings (Attach additional sheets if necessary)			
<p>Lagoon Cells #1 and #2 appeared to have a green tint. The water level of the final lagoon was below the highest discharge valve.</p> <p>An extensive amount of weeds were noted around the lagoons that need removed.</p> <p>The lowest effluent valve was observed leaking and needs repaired.</p>			
Inspector		Reviewer	
<p style="text-align: center;"><i>Ryan Gierhart</i> Ryan Gierhart Environmental Specialist II Division of Surface Water Northwest District Office</p>	<p style="text-align: center;"><i>Elizabeth A. Wick</i> Elizabeth A. Wick, P.E. Water Quality Engineer Division of Surface Water Northwest District Office</p>		
11-1-10 Date	11/1/10 Date		

Get New  
Data

Get Detail  
for Selected  
Permit

### Facilities in Significant Non-Compliance \*\*

Period: Apr-10 Sep-10

County	Permit #	Facility Name	Major	Station Code	Param Code	Parameter Name	Max % Exceed	# Months Signif Exceed (1)**	# Months Exceed (2)**
Fulton	2PB00045	Fayette WWTP		1	00530	Total Suspended Solids	84.6	1	4
Fulton	2PB00045	Fayette WWTP		1	31616	Fecal Coliform	620	3	3

Get New Data

Permit No	Reporting Period	Station	Reporting Code	Parameter	LimitType	Limit	Reported Value	Violation Date
2PB00045*GD	April 2010	001	00530	Total Suspended Solids	30D Conc	65	120.	4/1/2010
2PB00045*GD	April 2010	001	00530	Total Suspended Solids	7D Conc	90	134.	4/8/2010
2PB00045*GD	April 2010	001	00530	Total Suspended Solids	7D Conc	90	113.	4/22/2010
2PB00045*HD	May 2010	001	00530	Total Suspended Solids	30D Conc	65	65.75	5/1/2010
2PB00045*HD	May 2010	001	00530	Total Suspended Solids	7D Conc	90	112.	5/1/2010
2PB00045*HD	May 2010	001	31616	Fecal Coliform	30D Conc	1000	1303.44	5/1/2010
2PB00045*HD	May 2010	001	80082	CBOD 5 day	30D Conc	25	27.75	5/1/2010
2PB00045*HD	May 2010	001	80082	CBOD 5 day	7D Conc	40	53.	5/1/2010
2PB00045*HD	May 2010	001	31616	Fecal Coliform	7D Conc	2000	5813.77	5/8/2010
2PB00045*HD	June 2010	001	00530	Total Suspended Solids	30D Conc	65	88.	6/1/2010
2PB00045*HD	June 2010	001	31616	Fecal Coliform	30D Conc	1000	7200.	6/1/2010
2PB00045*HD	June 2010	001	80082	CBOD 5 day	30D Conc	25	32.	6/1/2010
2PB00045*HD	June 2010	001	31616	Fecal Coliform	7D Conc	2000	7200.	6/8/2010
2PB00045*HD	July 2010	001	00530	Total Suspended Solids	30D Conc	65	77.5	7/1/2010
2PB00045*HD	July 2010	001	31616	Fecal Coliform	30D Conc	1000	1800.	7/1/2010
2PB00045*HD	July 2010	001	80082	CBOD 5 day	30D Conc	25	57.	7/1/2010
2PB00045*HD	July 2010	001	80082	CBOD 5 day	7D Conc	40	57.	7/1/2010