



State of Ohio Environmental Protection Agency

**Northwest District Office**

347 North Dunbridge Rd.  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.ohio.gov

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Re: Fulton County  
Forest Park Mobile Home Park  
NPDES Permit

November 3, 2010

Mr. Mike Files, Owner  
Forest Park MHP  
P. O. Box 184  
Maumee, Ohio 43537

Dear Mr. Files:

On October 27, 2010, an operation and maintenance inspection was made of the wastewater treatment facility serving Forest Park MHP. The facility is located at 4549 C.R. E, Swan Creek Township, Fulton County. You and Mr. Dave Pike were present and provided operation and maintenance information. The discharge observed was clear, colorless and odorless.

A review of the discharge monitoring reports (DMRs) for January 2010 to October 2010 shows that there have been several NPDES permit effluent limit violations. The specific instances of noncompliance are attached on a separate sheet.

A copy of our completed inspection form is enclosed for your review. If you have any questions or comments, please contact me at (419) 373-3053.

Sincerely,

Ryan Gierhart  
Division of Surface Water

/cs

Enclosures

pc w/enc.: David Pike  
Fulton County Health Department  
NWDO-DSW-File

Get New Data

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PY00019*DD	January 2010	001	00530	Total Suspended Solids	30D Conc	12	17.	1/1/2010
2PY00019*DD	January 2010	001	00530	Total Suspended Solids	1D Conc	18	29.	1/13/2010
2PY00019*DD	May 2010	001	50060	Chlorine, Total Residu	1D Conc	0.019	.37	5/5/2010
2PY00019*DD	July 2010	001	50060	Chlorine, Total Residu	1D Conc	0.019	.05	7/1/2010

Average Daily Design Flow:	9,000 Gallons/Day
Plant Serves:	MHP
Average Daily Flow (Period of Review):	4,891 Gallons/Day (01/08 - 03/09)
Method of flow monitoring:	Estimate
Type of alarms for plant:	High water alarms

**Pretreatment**

Type of Pretreatment: **Trash Trap**  
 Does the Trash Trap need pumped: **Yes**  
 Maintenance of pretreatment components is: **Good**

**Comments/Status:**

Trash trap is pumped once per quarter.

**Secondary Treatment  
(Aeration)**

Color of sludge: **Medium Brown**  
 Quality of Sludge: **Medium**  
 Foam: **None present**  
 Odor: **No objectionable odor present**

	Yes	No		Yes	No
Aeration is taking place	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Plant is septic	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Blowers are operating	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Blowers are on a timer	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Skimmers are operating	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Plant is flooded	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Diffusers are operating	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Grating is present	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Sludge return is operating	<input checked="" type="checkbox"/>	<input type="checkbox"/>			

Maintenance of aerating equipment is...**Good**

**Comments/Status:**

Return Sludge Chocolate brown color. Some floc observed floating in clarifier. Chlorine tablets are being placed in aeration tanks to reduce floc.

**Secondary Treatment  
(Settling)**

Clarity: **Clear**  
 Condition of Weir: **Clean**  
 Weir is level: **Yes**

Effluent in weir: **Clear**  
 Clarifier walls need scraped: **Unknown**

Overall maintenance of settling components is: **Good**

**Comments/Status:**

Clarifier appeared clean and clear.

**Tertiary Treatment**

	Yes	No		Yes	No
Surface sand Filters: <b>Slow</b>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<b>None</b>	<input type="checkbox"/>	<input type="checkbox"/>
Distribution box operating	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Beds alternated	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Are filters ponding/flooding	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Beds raked	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Sand filters overgrown	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Chlorination present	<input checked="" type="checkbox"/>	<input type="checkbox"/>
UV present	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Dechlorination present	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Overall maintenance of components is: **Fair**

**Comments/Status:**

Ponding observed on sand filters. Sand filters need cleaned and raked.

**Sludge Handling/Storage/Disposal**

Hauler name: **Lyons Septic**  
 Disposal Site: **Delta WWTP**  
 Sludge wasted from: **Clarifier**  
 How often is sludge wasted: **As needed**  
 Sludge drying beds: **No**                      Sludge holding tank: **Yes**

Overall maintenance of components is: **Good**

**Comments/Status:**

Sludge removed from sludge holding tanks in June.

**Plant Discharge**

Discharge point is a: **Stream**  
 Name of discharge point: **Fewless Creek**  
 Discharge is visible: **Yes**                      Quality of Effluent: **Clear**

**Comments/Status:**

Effluent was observed was clear with no noticeable odor.

**Ryan Gierhart - Violation Forrest Mobile**

---

**From:** Wastewater Treat pla <wauseonwrp@embarqmail.com>  
**To:** Ryan Gierhart <ryan.gierhart@epa.state.oh.us>  
**Date:** 2/12/2010 11:43 AM  
**Subject:** Violation Forrest Mobile  
**CC:** Elizabeth Wick <Elizabeth.Wick@epa.state.oh.us>

---

Dear Mr. Gierhart

This letter is to inform you of a Suspended Solids violation for Forrest Mobile Home Park. Suspended Solids were reported for the week of January 13th as 29 mg/l. We removed 2000 gallons of sludge, and were back in compliance the week of the 27th, reported as 5 mg/l. If you need any more information please call me at 419-335-3026.

Thank you,

Dave Pike