



State of Ohio Environmental Protection Agency

**Northwest District Office**

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Re: Notice of Violation  
Fulton County  
Franklin Elementary School  
Ohio EPA Permit No. 2PT00050  
NPDES Permit No. OH0138754

December 5, 2007

Mr. David Hankins  
Superintendent  
Gorham - Fayette Local Schools  
P.O. Box 309  
Fayette, Ohio 43521

Dear Mr. Hankins:

We are in receipt of your self-monitoring report covering the months of July 2007, through September 2007, for the referenced facility. Our review indicates a violation of the conditions of your NPDES permit. The specific instances of noncompliance are attached on a separate sheet.

Please inform this office in writing as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.


Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures; and records retention, as specified in your Part III-General conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets or U. S. EPA's "Facility Pollution Prevention Guide" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614) 644-3469.

Mr. David Hankins  
December 5, 2007  
Page 2

If there are any questions, please contact me at (419) 373-3022.

Sincerely,



Justin A. Williams  
Division of Surface Water

//lr

Enclosure

pc w/enclosure:

 [DSW-NWDO-File]

Eric Kurfis Clean Water Service, Inc.

Get New Data

Violations for Franklin Elementary School - July thru September 2007

Permit No	Reporting Period	Violation Date	Station	Reporting Code	Parameter	Sample Frequency	Expected	Reported
2PT00050*AD	July 2007	7/1/2007	001	00010	Water Temperature	1/Week	1	0
2PT00050*AD	July 2007	7/8/2007	001	00010	Water Temperature	1/Week	1	0
2PT00050*AD	July 2007	7/22/2007	001	00010	Water Temperature	1/Week	1	0