



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

RE: Notice of Violation  
Fulton County  
Pettisville Sewer District  
Pleasant View Subdivision  
NPDES Permit

August 17, 2009

Mr. Leon L. Smith, Plant Operator  
28 Willow Way  
Archbold, Ohio 43502

Dear Mr. Smith:

We are in receipt of your self-monitoring reports covering the months of April through June 2009 for the referenced facilities. Our review indicates violations of the conditions of both NPDES permits. The specific instances of noncompliance are attached on separate sheets.

We have received your May 12, 2009, June 15, 2009, and July 10, 2009 letters regarding the attached violations. No further response is needed at this time.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in your Part III-General conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets or U. S. EPA's "Facility Pollution Prevention Guide" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614)644-3469.

If there are any questions, please contact me at (419) 373 - 3022.

Sincerely,

Justin A. Williams  
Division of Surface Water

/csl

Enclosure

Pc w/Enclosure:

\*NWDO - DSW File\

Mr. Ziad Musallam, Fulton County Sanitary Engineer

Get New Data

Violations for Pettisville WWTP - April - June 2009

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PG00014*JD	April 2009	001	00530	Total Suspended Solids	30D Conc	65	93.1666	4/1/2009
2PG00014*JD	April 2009	001	80082	CBOD 5 day	30D Conc	25	27.85	4/1/2009
2PG00014*JD	April 2009	001	00530	Total Suspended Solids	7D Conc	90	135.5	4/22/2009

Get New Data

Violations for Pleasant View Subdivision - April - June 2009

Permit No.	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PG00109*BD	May 2009	001	31616	Fecal Coliform	30D Conc	1000	2700.	5/1/2009
2PG00109*BD	May 2009	001	31616	Fecal Coliform	7D Conc	2000	2700.	5/8/2009
2PG00109*BD	June 2009	001	00300	Dissolved Oxygen	1D Conc	5.0	4.5	6/4/2009
2PG00109*BD	June 2009	001	00300	Dissolved Oxygen	1D Conc	5.0	4.1	6/10/2009
2PG00109*BD	June 2009	001	00300	Dissolved Oxygen	1D Conc	5.0	4.4	6/15/2009
2PG00109*BD	June 2009	001	00300	Dissolved Oxygen	1D Conc	5.0	3.3	6/22/2009