



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Notice of Violation
Fulton County
Pleasant View Subdivision
Ohio EPA Permit No. 2PG00109
NPDES Permit No. OH0122424

February 7, 2008

Mr. Leon L. Smith
Plant Operator
28 Willow Way
Archbold, Ohio 43502

Dear Mr. Smith:

We are in receipt of your self-monitoring reports covering the months of October 2007, through December 2007, for the referenced facility. Our review indicates violations of the conditions of the NPDES permit. The specific instances of noncompliance are attached on a separate sheet.

We have received your letter dated November 5, 2007, addressing the dissolved oxygen violations. No further response is needed regarding those violations. You need only to address the fecal coliform violations.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in your Part III-General conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets or U. S. EPA's "*Facility Pollution Prevention Guide*" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614) 644-3469.

Mr. Leon L. Smith
February 6, 2008
Page 2

If there are any questions, please contact me at (419) 373-3022.

Sincerely,



Justin A. Williams
Division of Surface Water

/lr

Enclosure

pc w/Enclosure: DSW\NWDO\File
Mr. Ziad Musallam, Fulton County Sanitary

Get New Data

Pleasant View Subdivision Violations - October thru December 2007

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PG00109*BD	October 2007	001	31616	Fecal Coliform	30D Conc	1000	9800.	10/1/2007
2PG00109*BD	October 2007	001	31616	Fecal Coliform	7D Conc	2000	9800.	10/8/2007
2PG00109*BD	October 2007	001	00300	Dissolved Oxygen	1D Conc	5.0	3.9	10/3/2007
2PG00109*BD	October 2007	001	00300	Dissolved Oxygen	1D Conc	5.0	3.8	10/9/2007
2PG00109*BD	October 2007	001	00300	Dissolved Oxygen	1D Conc	5.0	4.2	10/21/2007
2PG00109*BD	October 2007	001	00300	Dissolved Oxygen	1D Conc	5.0	4.2	10/23/2007