



State of Ohio Environmental Protection Agency

**Northwest District Office**

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

RE: Notice of Violation  
Fulton County  
Airport Industrial Park  
Pettisville Sewer District  
(Pleasant View Subdivision)  
NPDES Permit

November 14, 2008

Mr. Leon L. Smith  
Plant Operator  
28 Willow Way  
Archbold, OH 43502

Dear Mr. Smith:

We are in receipt of your self-monitoring reports covering the months of April 2008 through September 2008 for the referenced facilities. Our review indicates violations of the conditions of those NPDES permits. The specific instances of noncompliance are attached on separate sheets. Further review of your self-monitoring reports for the previous six months, ending in September 2008, for Airport Industrial Park indicates that you are in significant non-compliance (SNC) with an effluent limitation contained in your NPDES permit. The specific instance of SNC is attached on a separate sheet.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in your Part III-General conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets or U. S. EPA's "Facility Pollution Prevention Guide" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614)644-3469.

If there are any questions, please contact me at (419) 373-3022.

Sincerely,

Justin A. Williams  
Division of Surface Water  
/csl

Enclosure

Pc w/Enclosure:

CNWDO File

Mr. Ziad Musallam, Fulton County Sanitary Engineer

Get New Data

Pleasant View Subdivision April-June 2008 Violations

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PG00109*BD	May 2008	001	31616	Fecal Coliform	30D Conc	1000	3000.	5/1/2008
2PG00109*BD	May 2008	001	31616	Fecal Coliform	7D Conc	2000	3000.	5/1/2008
2PG00109*BD	June 2008	001	00300	Dissolved Oxygen	1D Conc	5.0	4.9	6/5/2008
2PG00109*BD	June 2008	001	00300	Dissolved Oxygen	1D Conc	5.0	4.9	6/10/2008
2PG00109*BD	June 2008	001	00300	Dissolved Oxygen	1D Conc	5.0	4.5	6/17/2008
2PG00109*BD	June 2008	001	00300	Dissolved Oxygen	1D Conc	5.0	4.8	6/23/2008

Get New Data

Pleasant View Subdivision July-September 2008 Violations

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PG00109*BD	July 2008	001	31616	Fecal Coliform	30D Conc	1000	1200.	7/1/2008
2PG00109*BD	July 2008	001	00300	Dissolved Oxygen	1D Conc	5.0	4.4	7/17/2008
2PG00109*BD	July 2008	001	00300	Dissolved Oxygen	1D Conc	5.0	4.7	7/23/2008
2PG00109*BD	August 2008	001	00300	Dissolved Oxygen	1D Conc	5.0	4.6	8/7/2008
2PG00109*BD	August 2008	001	00300	Dissolved Oxygen	1D Conc	5.0	4.9	8/14/2008
2PG00109*BD	August 2008	001	00300	Dissolved Oxygen	1D Conc	5.0	4.8	8/18/2008
2PG00109*BD	August 2008	001	00300	Dissolved Oxygen	1D Conc	5.0	4.8	8/26/2008
2PG00109*BD	September 2008	001	00300	Dissolved Oxygen	1D Conc	5.0	4.4	9/2/2008
2PG00109*BD	September 2008	001	00300	Dissolved Oxygen	1D Conc	5.0	4.4	9/8/2008
2PG00109*BD	September 2008	001	00300	Dissolved Oxygen	1D Conc	5.0	4.5	9/16/2008
2PG00109*BD	September 2008	001	00300	Dissolved Oxygen	1D Conc	5.0	4.4	9/23/2008