



State of Ohio Environmental Protection Agency

Northwest District Office

347 North Dunbridge Road
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Re: Notice of Violation
Fulton County
Swanton Meadows MHP
Ohio EPA Permit No. 2PY00022
NPDES Permit No. OH0122149

February 5, 2008

Ms. Carol Snyder, Property Manager
Swanton Meadows MHP
2170 S. Berkey Southern Road
Swanton, Ohio 43558

Dear Ms. Snyder:

We are in receipt of your self-monitoring report covering the months of October 2007, through December 2007, for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance are attached on a separate sheet. Further review of your self-monitoring reports for the previous six months, ending in December 2007, indicates that you are in significant non-compliance (SNC) with an effluent limitation contained in your NPDES permit. The specific instance of SNC is attached on a separate sheet.

Please inform this office in writing as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in your Part III-General conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner.

Ms. Carol Snyder, Property Manager


February 5, 2008

Page 2

You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets or U. S. EPA's "*Facility Pollution Prevention Guide*" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614)644-3469.

If there are any questions, please contact me at (419) 373-3022.

Sincerely,



Justin A. Williams

Division of Surface Water

//lr

Enclosure

pc w/enclosure:

~~CDSW-NWDO:File~~

Daniel Ware, IFM

Get New Data

Violations for Swanton Meadows MHP - October thru December 2007

| Permit No | Reporting Period | Station | Reporting Code | Parameter | Limit Type | Limit | Reported Value | Violation Date |
|-------------|------------------|---------|----------------|------------------------|------------|-------|----------------|----------------|
| 2PY00022*CD | November 2007 | 001 | 00530 | Total Suspended Solids | 1D Conc | 18 | 21.7 | 11/19/2007 |

| Permit No | Reporting Period | Station | Reporting Code | Parameter | Sample Frequency | Expected | Reported | Violation Date |
|-------------|------------------|---------|----------------|-------------------|------------------|----------|----------|----------------|
| 2PY00022*CD | November 2007 | 001 | 00010 | Water Temperature | 1/Day | 1 | 0 | 11/02/2007 |
| 2PY00022*CD | November 2007 | 001 | 00010 | Water Temperature | 1/Day | 1 | 0 | 11/03/2007 |
| 2PY00022*CD | November 2007 | 001 | 00010 | Water Temperature | 1/Day | 1 | 0 | 11/04/2007 |
| 2PY00022*CD | November 2007 | 001 | 00010 | Water Temperature | 1/Day | 1 | 0 | 11/06/2007 |
| 2PY00022*CD | November 2007 | 001 | 00010 | Water Temperature | 1/Day | 1 | 0 | 11/08/2007 |
| 2PY00022*CD | November 2007 | 001 | 00010 | Water Temperature | 1/Day | 1 | 0 | 11/10/2007 |
| 2PY00022*CD | November 2007 | 001 | 00010 | Water Temperature | 1/Day | 1 | 0 | 11/11/2007 |
| 2PY00022*CD | November 2007 | 001 | 00010 | Water Temperature | 1/Day | 1 | 0 | 11/13/2007 |
| 2PY00022*CD | November 2007 | 001 | 00010 | Water Temperature | 1/Day | 1 | 0 | 11/15/2007 |
| 2PY00022*CD | November 2007 | 001 | 00010 | Water Temperature | 1/Day | 1 | 0 | 11/17/2007 |
| 2PY00022*CD | November 2007 | 001 | 00010 | Water Temperature | 1/Day | 1 | 0 | 11/18/2007 |
| 2PY00022*CD | November 2007 | 001 | 00010 | Water Temperature | 1/Day | 1 | 0 | 11/20/2007 |
| 2PY00022*CD | November 2007 | 001 | 00010 | Water Temperature | 1/Day | 1 | 0 | 11/22/2007 |
| 2PY00022*CD | November 2007 | 001 | 00010 | Water Temperature | 1/Day | 1 | 0 | 11/24/2007 |
| 2PY00022*CD | November 2007 | 001 | 00010 | Water Temperature | 1/Day | 1 | 0 | 11/25/2007 |
| 2PY00022*CD | November 2007 | 001 | 00010 | Water Temperature | 1/Day | 1 | 0 | 11/27/2007 |
| 2PY00022*CD | November 2007 | 001 | 00010 | Water Temperature | 1/Day | 1 | 0 | 11/29/2007 |

Get New
Data

Get Detail
for Selected
Permit

Facilities in Significant Non-Compliance **

Period: Jul-07 Dec-07

| County | Permit # | Facility Name | Major | Station Code | Param Code | Parameter Name | Max % Exceed | # Months Signif Exceed (1)** | # Months Exceed (2)** |
|--------|----------|---------------------|-------|--------------|------------|--------------------------|--------------|------------------------------|-----------------------|
| Fulton | 2PY00022 | Swanton Meadows MHP | | 1 | 50060 | Chlorine, Total Residual | 689.5 | 2 | 2 |