



State of Ohio Environmental Protection Agency

**Northwest District Office**

347 North Dunbridge Road  
Bowling Green, OH 43402-9398

TELE: (419) 352-8461 FAX: (419) 352-8468  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

RE: Notice of Violation  
Fulton County  
Wauseon WWTP  
Ohio EPA Permit No. 2PD00016  
NPDES Permit No. OH0023400

November 14, 2008

Mr. Dave Pike  
WRP Superintendent  
City of Wauseon  
230 Clinton Street  
Wauseon, OH 43567

Dear Mr. Pike:

We are in receipt of your self-monitoring report covering the months of April 2008 through June 2008 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance are attached on a separate sheet.

Please inform this office in writing as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in your Part III-General conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets or U. S. EPA's "*Facility Pollution Prevention Guide*" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614)644-3469.

Mr. Dave Pike  
November 14, 2008  
Page 2

If there are any questions, please contact me at (419) 373-3022.

Sincerely,



Elizabeth A. Wick, P.E.  
District Engineer/Unit Supervisor  
Division of Surface Water

/csl

Enclosure

ⓈPc w/Enclosure: NWDO - DSW File'

Get New Data

Wauseon LUTP April-June 2008 Violations

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PD00016*HD	June 2008	001	50060	Chlorine, Total Residu	1D Conc	0.016	.18	6/3/2008
2PD00016*HD	June 2008	001	50060	Chlorine, Total Residu	1D Conc	0.016	.16	6/4/2008