



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Hancock County
Village of McComb Water Treatment Plant
NPDES Permit

February 14, 2011

Mr. Kevin Siferd, Village Administrator
Village of McComb
210 East Main Street
P. O. Box 340
McComb, Ohio 45858

Dear Mr. Siferd:

On November 9, 2010, a pre-permit inspection was made of the wastewater treatment facilities serving the water treatment plant for the Village of McComb. Mr. Doug Keller was present and provided information about the plant.

The wastewater lagoon that collects the sludge from the water treatment process was full of solids. Mr. Keller indicated that it will be cleaned out in the spring of this year. Sodium thiosulfate is being used to remove chlorine from the wastewater stream. Mr. Keller stated that the plant is working on the dosage to eliminate chlorine violations.

A review of your discharge monitoring reports indicates limit violations for the months of March 2006 through November 2010. The specific instances of non-compliance are attached.

If you have any questions regarding the inspection, please contact me at 419-373-3019.

Sincerely,


Michelle Sharp

/llr

pc: Hancock County Health Department
DSW:NWDO.File

Violation Date	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value
5/7/2006	001	50060	Chlorine, Total Residu	1D Conc	0.019	.11
5/12/2006	001	50060	Chlorine, Total Residu	1D Conc	0.019	.41
5/19/2006	001	50060	Chlorine, Total Residu	1D Conc	0.019	.16
5/24/2006	001	50060	Chlorine, Total Residu	1D Conc	0.019	.06
9/12/2007	001	50060	Chlorine, Total Residu	1D Conc	0.019	.45
10/8/2007	001	00530	Total Suspended Solids	1D Conc	45	54.
12/28/2007	001	50060	Chlorine, Total Residu	1D Conc	0.019	.1
5/2/2008	001	00530	Total Suspended Solids	1D Conc	45	68.
8/1/2008	001	50060	Chlorine, Total Residu	1D Conc	0.019	.07
11/20/2008	001	00530	Total Suspended Solids	1D Conc	45	68.
12/26/2008	001	00530	Total Suspended Solids	1D Conc	45	49.5
1/1/2009	001	00530	Total Suspended Solids	30D Conc	30	52.25
1/7/2009	001	00530	Total Suspended Solids	1D Conc	45	104.
1/14/2009	001	00530	Total Suspended Solids	1D Conc	45	53.
2/21/2009	001	50060	Chlorine, Total Residu	1D Conc	0.019	.05
5/13/2009	001	50060	Chlorine, Total Residu	1D Conc	0.019	.05
5/5/2010	001	50060	Chlorine, Total Residu	1D Conc	0.019	.07
5/20/2010	001	50060	Chlorine, Total Residu	1D Conc	0.019	.12
7/12/2010	001	50060	Chlorine, Total Residu	1D Conc	0.019	.06
9/7/2010	001	50060	Chlorine, Total Residu	1D Conc	0.019	.1
11/1/2010	001	50060	Chlorine, Total Residu	1D Conc	0.019	.06