

**Environmental  
Protection Agency**

Patricia A. ... Governor  
Lee Fisher, Lt. Governor  
Chris Koneski, Director

OH2600711 METAMORA VILLAGE

2950

02 11/18/10



\* 0 H 2 6 0 0 7 1 1 8 7 4 0 0 2 8 \*

November 18, 2010

CERTIFIED MAIL

**NOTICE OF VIOLATION – ACTION REQUIRED**

John Vershum  
Metamora Village  
114 E Main St, Po Box 299  
Metamora, OH 43540-0299

Fulton County  
Metamora Village  
Community PWS  
PWS ID: OH2600711

**Subject: Violation of Maximum Contaminant Level for TOTAL TRIHALOMETHANES (TTHM)**

Metamora Village is in violation for exceeding the maximum contaminant level (MCL) standard of 0.080 MG/L as established in the Ohio Administrative Code (OAC) section 3745-81-12 for TTHM. Compliance with the MCL is based on a running annual average. The annual average for TTHM during the Third Quarter of 2010 time period is 0.132 MG/L.

**To address the MCL violation, Metamora Village is required to take the following actions:**

1. Notify your customers within 30 days using the enclosed instructions and public notice.
2. Complete and send a verification form with a copy of the public notice to the above mailing address within ten days after issuance.
3. Perform quarterly monitoring for TTHM during each calendar quarter (January 1 – March 31; April 1 – June 30; July 1 – September 30; October 1 to December 31).
4. Consult with your Ohio EPA district representative to discuss your options for coming into compliance and establishing a compliance schedule or comply with any existing enforcement action that has been issued to you.

Your prompt attention to this matter is greatly appreciated. Continued noncompliance may lead to enforcement actions. If you have any questions or wish to change the public notice, please call me at (614) 644-2752.

Sincerely,

Sarah Byerly  
Compliance Assurance Section  
Division of Drinking and Ground Waters

Enclosure: Public Notice; Public Notice Instructions and Verification Form  
cc: Manager; DDAGW file; NWDO file; Fulton County Health Department