



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

January 11, 2008

RE: ASHTABULA COUNTY  
ASHCRAFT WWT FACILITY  
OHIO EPA PERMIT NO. 3PG00150  
COMPLIANCE INSPECTION LETTER

Mr. Larry Meaney  
Ashtabula County Department of Environmental Services  
25 West Jefferson Street  
Jefferson, OH 44047

Dear Mr. Meaney:

On January 8, 2007, the undersigned inspected the above facility for compliance with the NPDES permit. Upon inspection, the facility looked in good order.

A review of the monthly operating reports from December 1, 2005, through December 31, 2007, shows the following NPDES permit limit violations:

**Limit Violations**

Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
March 2006	001	Total Suspended Solids	30D Conc	12	16.5	3/1/2006
March 2006	001	Total Suspended Solids	7D Conc	18	51.	3/22/2006
October 2006	001	Fecal Coliform	30D Conc	1000	1075.26	10/1/2006
October 2006	001	Fecal Coliform	7D Conc	2000	3700.	10/1/2006
November 2006	001	Nitrogen, Ammonia (NH3)	7D Conc	1.5	1.6	11/15/2006
May 2007	001	Fecal Coliform	7D Conc	2000	2100.	5/1/2007

**Frequency Violations**


Reporting Period	Violation Date	Station	Parameter	Sample Frequency	Expected	Reported
March 2006	3/16/2006	001	Turbidity, Severity	1/Day	1	0
September 2006	9/15/2006	001	Color, Severity	1/Day	1	0
November 2006	11/1/2006	001	Fecal Coliform	1/Month	1	0

ASHCRAFT WWT FACILITY  
JANUARY 11, 2008  
PAGE 2

Given the above, the facility is considered to be in substantial compliance. Only one violation has occurred in 2007 which shows excellent operation of the facility.

If you have any questions, feel free to contact me at 330-963-1180.

Respectfully,

A handwritten signature in cursive script that reads "Virginia Wilson".

Virginia Wilson, P.E.  
Geological Engineer  
Division of Surface Water

VW/ams

File: Municipal/Ashtabula Ashcraft/P&C