



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

November 19, 2007

RE: ASHTABULA COUNTY
MEADOWOOD ALLOTMENT
OHIO EPA PERMIT NO. 3PG00075
COMPLIANCE INSPECTION LETTER

Mr. Larry Meaney
Ashtabula County Department of Environmental Services
25 West Jefferson Street
Jefferson, OH 44047

Dear Mr. Meaney:

October 19, 2007, the undersigned inspected the above facility for compliance with the National Pollutant Discharge Elimination System (NPDES) permit. Upon inspection, the facility looked in good order.

A review of the monthly operating reports from January 1, 2006, through November 1, 2007, shows the following NPDES permit limit violations:

Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
September 2006	001	Total Suspended Solids	30D Qty	1.8	4.37039	9/1/2006
September 2006	001	Total Suspended Solids	7D Qty	2.7	16.8621	9/1/2006
September 2006	001	Nitrogen, Ammonia (NH3)	30D Qty	0.3	.46067	9/1/2006
September 2006	001	Nitrogen, Ammonia (NH3)	7D Qty	0.5	.91056	9/1/2006
September 2006	001	CBOD 5 day	30D Qty	1.5	4.34137	9/1/2006
September 2006	001	CBOD 5 day	7D Qty	2.3	16.8621	9/1/2006
December 2006	001	Total Suspended Solids	7D Conc	18	26.	12/22/2006
September 2007	001	Chlorine, Total Residu	1D Conc	0.019	.1	9/17/2007
September 2007	001	Chlorine, Total Residu	1D Conc	0.019	.1	9/24/2007

Given the above, the facility is considered to be in substantial compliance. The facility should try to eliminate all of the above in the future.

If you have any questions, feel free to contact me at (330) 963-1180.

Respectfully,

Virginia Wilson, P.E.
Geological Engineer
Division of Surface Water

VW/mt

File: Municipal/Ashtabula Meadowood Allotment/P&C