

MEMORANDUM  
FOR THE DIRECTOR  
DATE: 7/28/09  
TO: [unclear]  
FROM: [unclear]



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

July 28, 2009

RE: - SKYVIEW ACERS  
SUNSET DRIVE  
COMPLIANCE EVALUATION INSPECTION  
NPDES PERMIT NO. 3PG00123  
YELLOW CREEK TOWNSHIP  
COLUMBIANA COUNTY

Mr. Troy Graft, P.E.  
Chief Engineer  
Columbiana County Engineer  
105 South Market Street  
Lisbon, OH 44432

Dear Mr. Graft:

On May 19, 2009, this writer conducted a compliance evaluation inspection of the Columbiana County Skyview Acers located at the above referenced address.

The following is a summary of the inspection:

- 1) At the time the wastewater treatment plant appeared to be operating satisfactorily. All units appeared operational. The influent baffle to the settling tank had some minor solids behind it. One half of the sand filter was clean; the other had some minor solids. The chlorine contact tank had both chemicals for chlorination and dechlorination.
- 2) This facility's NPDES permit expired in February 2009. The draft permit will be available for your review shortly.
- 3) A review of the effluent data from July 2006 through June 2009 revealed only one pH violation. Flow data did not indicate any excessive infiltration. The plant appears to be receiving adequate operation and maintenance.

Should you have any comments or questions, feel free to contact me at (330) 963-1193.

Respectfully,

Joseph E. Trocchio, P.E.  
Environmental Engineer  
Division of Surface Water

JET/mt

cc: Lori J. Barnes, R.S., Columbiana County Health Department  
Donald W. Harrison, Utilities Superintendent

File: Public/Permit Compliance/Columbiana County/ Skyview Acres WWTP