



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

October 14, 2008

RE: HOLMES CO.
WINESBURG NPDES #3PG00138
2008 CEI

Mr. Chris Young, P.E., P.S.
Holmes County Sanitary Engineer
P.O. Box 90
Millersburg, OH 44654

CERTIFIED MAIL

Dear Mr. Young:

On October 9, 2008, this office conducted a compliance evaluation inspection (CEI) of the Holmes County Winesburg Village Wastewater Treatment Plant (WWTP). Present during the inspection were this writer, Chris Young, Holmes County Sanitary Engineer and Kevin Dean, Wastewater Treatment Plant Operator, Dean's Backflow Services.

At the time of the inspection, the treatment system was producing a clear effluent that appeared to be of satisfactory quality.

The mixed liquor in the aeration tank had a very good color and the settling tank effluent was clear. The surface sand filters were in very good condition. The ultraviolet disinfection system was operational and the treatment system effluent was clear.

A review of your discharge monitoring reports (DMRs) covering the period September 2007 through August 2008 revealed the following effluent violations:

Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
January 2008	001	Total Suspended Solids	30D Conc	12	21.	1/1/2008
January 2008	001	Total Suspended Solids	7D Conc	18	21.	1/1/2008
February 2008	001	Dissolved Oxygen	1D Conc	6.0	4.6	2/8/2008
February 2008	001	Dissolved Oxygen	1D Conc	6.0	4.3	2/25/2008
February 2008	001	Dissolved Oxygen	1D Conc	6.0	4.8	2/26/2008
March 2008	001	Dissolved Oxygen	1D Conc	6.0	3.57	3/3/2008
April 2008	001	Phosphorus, Total (P)	30D Conc	1.0	1.59	4/1/2008
April 2008	001	Phosphorus, Total (P)	7D Conc	1.5	1.59	4/1/2008
April 2008	001	Phosphorus, Total (P)	30D Qty	0.057	.09027	4/1/2008
April 2008	001	Phosphorus, Total (P)	7D Qty	0.085	.09027	4/1/2008
April 2008	001	Dissolved Oxygen	1D Conc	6.0	5.42	4/22/2008
May 2008	001	Total Suspended Solids	30D Conc	12	13.	5/1/2008
May 2008	001	Phosphorus, Total (P)	30D Conc	1.0	1.02	5/1/2008
June 2008	001	CBOD 5 day	30D Conc	10	11.	6/1/2008
June 2008	001	CBOD 5 day	30D Qty	0.57	.62453	6/1/2008
June 2008	001	Phosphorus, Total (P)	30D Conc	1.0	1.73	6/1/2008
June 2008	001	Phosphorus, Total (P)	7D Conc	1.5	1.73	6/1/2008

MR. CHRIS YOUNG
WINESBURG NPDES #3PG00138
OCTOBER 14, 2008
PAGE 2

Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
June 2008	001	Phosphorus, Total (P)	30D Qty	0.057	.09822	6/1/2008
June 2008	001	Phosphorus, Total (P)	7D Qty	0.085	.09822	6/1/2008
July 2008	001	Dissolved Oxygen	1D Conc	6.0	3.32	7/8/2008
July 2008	001	Dissolved Oxygen	1D Conc	6.0	5.77	7/15/2008

Should you have any questions or comments regarding this letter, please contact this office at (330) 963-1197.

Sincerely,



Dean W. Stoll, P.E.
Environmental Engineer
Division of Surface Water

DWS/mlh

pc: Holmes County Commissioners
Andrea Salimbene, AGO

ec: Kevin Dean

File: Public/Permit Compliance

SENDER: COMPLETE THIS SECTION	COMPLETE THIS SECTION ON DELIVERY
<ul style="list-style-type: none"> Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired. Print your name and address on the reverse so that we can return the card to you. Attach this card to the back of the mailpiece, or on the front if space permits. 	<p>A. Signature <i>x Mary Troyer</i> <input type="checkbox"/> Agent <input type="checkbox"/> Addressee</p> <p>B. Received by (Printed Name) <i>Mary Troyer</i></p> <p>C. Date of Delivery <i>10-14-08</i></p>
<p>1. Article Addressed to:</p> <p>Mr. Chris Young, P.E., P.S. Holmes County Sanitary Engineer P.O.Box 90 Millersburg, OH 44654</p>	<p>D. Is delivery address different from item 1? <input type="checkbox"/> YES <input type="checkbox"/> NO If YES, enter delivery address below:</p> <p>3. Service Type <input checked="" type="checkbox"/> Certified Mail <input type="checkbox"/> Express Mail <input type="checkbox"/> Registered <input type="checkbox"/> Return Receipt for Merchandise <input type="checkbox"/> Insured Mail <input type="checkbox"/> C.O.D.</p> <p>4. Restricted Delivery? (Extra Fee) <input type="checkbox"/> Yes <input type="checkbox"/> No</p>
<p>2. Article Number 7008 0150 0001 7110 8707 (Transfer from service label)</p>	<p>D. Stoll 10-14-08</p>

PS Form 3811, February 2004 Domestic Return Receipt 102595-02-M-1540

U.S. Postal Service
CERTIFIED MAIL RECEIPT
 (Domestic Mail Only; No Insurance Coverage Provided)

For delivery information visit our website at www.usps.com

PROHIBITED USE

Postage	\$	Postmark Here D. Stoll 10-14-08 <i>meh</i>
Certified Fee		
Return Receipt Fee (Endorsement Required)		
Restricted Delivery Fee (Endorsement Required)		
Total Postage & Fees	\$	

Sent To Mr. Chris Young, P.E., P.S.
Holmes County Sanitary Engineer
 Street, Apt. No., or PO Box No. P.O. Box 90
 City, State, ZIP+4 Millersburg, OH 44654

PS Form 3800, August 2006 See Reverse for Instructions

7008 0150 0001 7110 8707

