



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

January 7, 2008

RE: PUBLIC WASTEWATER
BOARDMAN WWTP
NPDES PERMIT NO. 3PK00002

NOTICE OF VIOLATION

Board of Mahoning County Commissioners
21 West Boardman Street
Youngstown, OH 44503

Gentlemen:


A review of monitoring data shows that over the period covering June through November 2007, the Boardman POTW is listed as being in Significant Noncompliance with the NPDES Permit limit on phosphorus. All of the permit violations identified during the review period are as follows.

Report Period	Station	Parameter	Limit Type	Limit	Reported Value	Units	Violation Date
Jul 2007	001	Phosphorus, Total (P)	30-Day Conc.	1.0	1.01667	mg/l	7/1/2007
Jul 2007	001	Phosphorus, Total (P)	7-Day Conc.	1.5	2.3	mg/l	7/1/2007
Sep 2007	001	Phosphorus, Total (P)	30-Day Conc.	1.0	1.6	mg/l	9/1/2007
Sep 2007	001	Phosphorus, Total (P)	7-Day Conc.	1.5	2.15	mg/l	9/15/2007
Sep 2007	001	Phosphorus, Total (P)	7-Day Conc.	1.5	1.8	mg/l	9/22/2007
Oct 2007	001	Phosphorus, Total (P)	30-Day Conc.	1.0	1.44286	mg/l	10/1/2007
Oct 2007	001	Phosphorus, Total (P)	7-Day Conc.	1.5	2.4	mg/l	10/8/2007
Sep 2007	001	Fecal Coliform	7-Day Conc.	2000	5552.38	#/100 ml	9/15/2007
Jul 2007	001	pH, Minimum	1-Day Conc.	6.5	6.3	s.u.	7/23/2007
Oct 2007	001	pH, Minimum	1-Day Conc.	6.5	6.3	s.u.	10/17/2007

Mahoning County must provide a written response to this office indicating the cause of the violations and actions that have been taken to bring the treatment system into compliance with the NPDES Permit. The response should be provided no later than January 25, 2008.

Be advised that violations of the NPDES Permit are subject to fines and other enforcement actions in accordance with ORC 6111.

Respectfully,


John Kwolek
District Engineer
Division of Surface Water

JK:bo

cc. Mr. Joseph Warino, County Sanitary Engineer
Al Deibel, Mahoning County Boardman POTW
Tom Behlen, AGO/EES