

OHIO
State of Ohio Environmental Protection Agency
Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

October 22, 2008

RE: Portage County
Randolph WWTP
Compliance Inspection

Mr. Wayne Carkido
Portage County Water Resources
449 South Meridian Street
Ravenna, OH 44266-1217

Dear Mr. Carkido:

This letter shall serve to document an unannounced inspection of the above wastewater treatment plant conducted on October 17, 2008.

At the time of my inspection the plant appeared well run and operated. It was producing a clear effluent.

A review of monthly operating report data for the time period November 2006 thru September 2008 indicates the following effluent limit violations:

Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
August 2007	001	Ammonia	7D Conc	1.5	1.725	8/22/2007
August 2007	001	pH	1D Conc	6.5	6.4	8/6/2007
August 2007	001	pH	1D Conc	6.5	6.3	8/8/2007
August 2007	001	pH	1D Conc	6.5	6.4	8/10/2007

It does appear that the plant flow is beginning to increase as additional users are being connected. The graph on the following page shows results of all flow data generated to date at the facility. Flows are currently averaging about 50,000 gpd.

Should you have any further questions please do not hesitate to call me at 330/963-1134.

Sincerely,



William J. Zawiski
Environmental Scientist
Division of Surface Water

