



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.  
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

May 4, 2009

RE: PORTAGE COUNTY  
TWIN LAKES WWTP  
NPDES #3PH00038

Mr. Harold Huff  
Portage County Water Resources  
449 S. Meridian Street  
Ravenna, OH 44266

Dear Mr. Huff:

This office conducted a compliance inspection at the above treatment plant on May 1, 2009.

A computer review of monthly operating reports for the time period November 2008 through March 2009 indicated the following effluent limit violations:

Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
February 2009	001	Total Suspended Solids	7D Qty	20.7	28.5792	2/8/2009

Overall the plant is well run and operated and producing an acceptable effluent.

At the time of my inspection the west aeration tank was empty and being cleaned for painting. The UV disinfection units were in place and operating.

Should you have further questions, please call me at (330) 963-1134.

Sincerely,

William J. Zawiski  
Environmental Scientist  
Division of Surface Water

WJZ/mt

cc: Wayne Carkido, Portage County Water Resources