



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

December 22, 2008

RE: STARK COUNTY
BOB-O-LINK ALLOTMENT WWTP
NPDES #3PG00082

Mr. Michael Armogida, Director
Stark County Sanitary Engineer
1701 Mahoning Road NE
Canton, OH 44705

Dear Mr. Armogida:

A compliance evaluation inspection (CEI) of the sewage treatment plant serving the Bob-O-Link Allotment was conducted by this writer on December 17, 2008.

At the time of the inspection, the treatment plant was in very good operation and maintenance condition.

The mixed liquor in the aeration tank had a very good color and the settling tank effluent was clear. Odors from the treatment system were minimal. Three of the four rapid sand filter units were on-line and no solids were noted in the chlorine contact tank. The treatment system was producing a clear effluent that appeared to be of exceptional quality.

The final effluent flow meter was not registering any flow and the screen message read "power failed".

A review of your Discharge Monitoring Reports (DMRs) covering the period October 2006 through October 2008 revealed the following effluent violations:

Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
October 2007	001	Nitrogen, Ammonia (NH3)	30D Conc	1.5	1.6225	10/1/2007
October 2007	001	Nitrogen, Ammonia (NH3)	7D Conc	2.3	3.425	10/15/2007
October 2007	001	pH	1D Conc	6.5	6.1	10/22/2007
September 2008	001	Nitrogen, Ammonia (NH3)	30D Conc	1.5	2.59625	9/1/2008
September 2008	001	Nitrogen, Ammonia (NH3)	7D Conc	2.3	10.055	9/15/2008
September 2008	001	Nitrogen, Ammonia (NH3)	7D Qty	2.6	4.53642	9/15/2008

Overall, the results of the inspection were satisfactory. If you have any questions or comments regarding this letter, please contact this office at (330) 963-1197.

Sincerely,

Dean W. Stoll, P.E.
Environmental Engineer
Division of Surface Water

DWS/mt

cc: Mark Daverio, O&M Supervisor, Stark County Sanitary Engineer
Stark County Commissioners

File: Public/Permit Compliance