

**Environmental
Protection Agency**

_____, Governor
_____, Lt. Governor
_____, Director

May 26, 2010

RE: STARK COUNTY
BOB-O-LINK ALLOTMENT WWTP
NPDES #3PG00082

Mr. James Jones, Sanitary Engineer
Stark County Sanitary Engineering Department
P.O. Box 7906
1701 Mahoning Road NE
Canton, OH 44705

Dear Mr. Jones:

A compliance evaluation inspection (CEI) of the sewage treatment plant serving the Bob-O-Link Allotment was conducted by this writer on May 20, 2010. Present during the inspection was Mark Daverio, O&M Supervisor, Stark County Sanitary Engineer.

At the time of the inspection, the treatment plant was in good operation and maintenance condition.

The mixed liquor in the aeration tank had a very good color and the settling tank effluent was clear. There were no odors from the treatment system. No solids were noted in the chlorine contact tank and the system was producing what appeared to be a quality effluent.

A review of your Discharge Monitoring Reports (DMRs) covering the period November 2008 through March 2010 revealed the following effluent violations:

Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
October 2009	001	Oil and Grease, Total	1D Conc	10	11.	10/14/2009
August 2009	001	Nitrogen, Ammonia (NH3)	7D Conc	2.3	2.665	8/8/2009
August 2009	001	Oil and Grease, Total	1D Conc	10	11.	8/11/2009

Overall, the results of the inspection were satisfactory. Should you have any questions or comments regarding this letter, please contact this office at (330) 963-1255.

Sincerely,



Todd Surrena
Engineering Geologist
Division of Surface Water

TMS/mt

cc: Mark Daverio, O&M Supervisor, Stark County Sanitary Engineer

File: Public/Permit Compliance