



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

December 22, 2008

RE: STARK COUNTY
MAGNOLIA VILLAGE WWTP
NPDES #3PH00053

Mr. Michael Armogida, Director
Stark County Sanitary Engineer
1701 Mahoning Road NE
Canton, OH 44705

Dear Mr. Armogida:

A compliance evaluation inspection (CEI) of the sewage treatment plant serving the Village of Magnolia was conducted by this writer on December 17, 2008.

At the time of the inspection, the treatment plant was in good operation and maintenance condition and was producing what appeared to be a satisfactory quality effluent. Odors from the lagoon system were minimal.

The mechanical surface aerators have been removed from the lagoons for the winter.

A review of your Discharge Monitoring Reports (DMRs) covering the period October 2006 through October 2008 revealed the following effluent violations:

Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
December 2006	001	Oil and Grease, Total	1D Conc	10	14.	12/5/2006
July 2007	001	Oil and Grease, Total	1D Conc	10	33.	7/10/2007

Overall, the results of the inspection were satisfactory. Should you have any questions or comments regarding this letter, please feel free to contact this office at (330) 963-1197.

Sincerely,

Dean W. Stoll, P.E.
Environmental Engineer
Division of Surface Water

DWS/mt

cc: Mark Daverio, O&M Supervisor, Stark County Sanitary Engineer
Stark County Commissioners

File: Public/Permit Compliance