



State of Ohio Environmental Protection Agency

Northeast District Office

2110 East Aurora Rd.
Twinsburg, Ohio 44087

TELE: (330) 963-1200 FAX: (330) 487-0769
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

February 13, 2009

RE: Summit County
Interstate Industrial Park WWTP #44
Compliance Evaluation Inspection (CEI)
Ohio EPA Permit No. 3PG00116*FD

Mr. Dave Marquard, Director
Summit County Department of Environmental Services
2525 State Road
Cuyahoga Falls, OH 44223-1602

Dear Mr. Marquard:

On February 6, 2009, a Compliance Evaluation Inspection was conducted at the above referenced wastewater treatment plant by this office. A thorough inspection did not take place because the fence was locked; but it was noted that the plant was running.

According to our files, the 10,000 gpd wastewater treatment plant consists of a trash trap, extended aeration, settling, surface sand filters, ultraviolet disinfection, and sludge holding. It was understood that for several years the plant was not discharging to Wolf Creek. Rather, all wastewater was being hauled to the Summit County Upper Tuscarawas WWTP #36. According to our SWIMS database, it appears that as of November 8, 2007, the plant has again been discharging.

Upon review of Summit County's electronic discharge monitoring reports from February 2006 to February 2009, it was noted the plant experienced the following effluent violations:


Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
January 2008	Nitrogen, Ammonia (NH3)	30D Conc	5.2	7.94	1/1/2008
January 2008	Nitrogen, Ammonia (NH3)	7D Conc	7.8	14.	1/22/2008
January 2008	Nitrogen, Ammonia (NH3)	7D Qty	0.3	.31794	1/22/2008
February 2008	Nitrogen, Ammonia (NH3)	30D Conc	5.2	8.46667	2/1/2008
February 2008	Nitrogen, Ammonia (NH3)	7D Conc	7.8	14.	2/8/2008
February 2008	CBOD 5 day	7D Conc	15	16.	2/8/2008
April 2008	Nitrogen, Ammonia (NH3)	30D Conc	5.2	6.4	4/1/2008
April 2008	Nitrogen, Ammonia (NH3)	7D Conc	7.8	9.65	4/8/2008
April 2008	Dissolved Oxygen	1D Conc	6.0	5.9	4/19/2008
June 2008	Dissolved Oxygen	1D Conc	6.0	4.7	6/12/2008
June 2008	Dissolved Oxygen	1D Conc	6.0	5.9	6/13/2008
June 2008	Dissoived Oxygen	1D Conc	6.0	4.5	6/17/2008
June 2008	Dissoived Oxygen	1D Conc	6.0	3.7	6/18/2008
August 2008	Fecal Coliform	7D Conc	2000	19869.5	8/8/2008
August 2008	Fecal Coliform	7D Conc	2000	4800.	8/15/2008

Mr. Dave Marquard
Interstate Industrial Park WWTP #44
February 13, 2009
Page 2

Please be advised such instances of noncompliance are subject to enforcement pursuant to Ohio Revised Code 6111. Bob Hollis of Summit County DOES has been sending letters to Ohio EPA, explaining reasons for the violations and actions taken to alleviate the violations. Hopefully, the plant's problems have been solved.

If you have any questions, please contact this office at (330) 963-1151.

Sincerely,



Jennifer S. Bennage
Environmental Engineer
Division of Surface Water

JSB/mt

cc: Bob Hollis, Deputy Director of Operations