



Environmental Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

March 3, 2011

RE: Summit County
Interstate Industrial Park WWTP #44
NPDES No. OHOO45501
Ohio EPA No. 3PG00116
Pre-Permit/Compliance Inspection

Mr. David E. Marquard, Director
Summit County, Environmental Services
2525 State Road
Cuyahoga Falls, OH 44223

Dear Mr. Marquard:

On March 2, 2011, an NPDES pre-permit inspection was conducted by this writer of this office at the Interstate Industrial Park WWTP #44. A thorough inspection was not conducted because of the locked gate and the fact that the plant is currently not discharging.

According to our files, the 10,000 gpd wastewater treatment plant consists of a trash trap, extended aeration, settling, surface sand filters, ultraviolet disinfection, and sludge holding. Originally the plant was designed to discharge to Wolf Creek.

At the time of the inspection, the plant was not running. According to recent Discharge Monitoring Reports, as of January 22, 2011, Summit County has again stopped discharging effluent from this plant. All wastewater is being hauled to the Summit County Upper Tuscarawas WWTP #36 for treatment and discharge.

Review of the Discharge Monitoring Reports (DMRs) from March 2009 through March 2011 revealed the following numeric effluent violations:

Table with 7 columns: Station, Reporting Code, Parameter, Limit Type, Limit, Reported Value, Violation Date. Contains 3 rows of violation data.

The Public Notice of the draft renewal NPDES permit will be published in the local newspaper. Once Central Office sends you the draft permit, please read it carefully. A change in the renewal permit concerns E. coli.


A change in the State's Water Quality Standards is replacing the fecal coliform effluent limitation with an E. coli effluent limitation. Please note that your renewal permit's

Mr. David E. Marquard  
Interstate Industrial Park WWTP #44  
March 3, 2011  
Page 2

interim effluent table contains the fecal coliform limitation, but also includes E. coli monitoring. The final effluent table includes an E. coli effluent limitation instead of fecal coliform limitation. The Schedule of Compliance in your permit directs you to submit to this office, six months after the effective date of the permit, a brief status report on the ability of your existing treatment works to meet the final effluent limit for E. coli.

If you have any questions concerning this letter, please contact this office at (330) 963-1151.

Sincerely,



Jennifer S. Bennage  
Environmental Engineer  
Division of Surface Water

JSB/mt

cc: Robert Hollis, Summit County D.O.E.S.